

施設排ガス測定データ

2016年 6月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	水	3	3	2	2	2	2	7	8	3	2	6	5	26	28	18	16	21	22	0.00	0.00	0.00	0.00	0.00	0.00	41	36	8	8	22	24	
2	木	2	2	2	2	2	2	8	7	1	1	5	4	27	29	16	11	22	21	0.00	0.00	0.00	0.00	0.00	0.00	33	31	8	6	20	20	
3	金	3	2	2	2	2	2	7	8	1	2	5	5	29	28	11	11	21	20	0.00	0.00	0.00	0.00	0.00	0.00	40	31	19	18	28	26	
4	土	2	2	2	1	2	2	7	7	2	4	6	6	25	26	13	9	20	19	0.00	0.00	0.00	0.00	0.00	0.00	38	35	10	19	25	25	
5	日	2	2	2	2	2	2	8	8	6	5	7	6	28	28	14	14	20	21	0.00	0.00	0.00	0.00	0.00	0.00	36	35	15	10	26	24	
6	月	6	2	1	2	2	2	8	9	0	4	6	6	26	23	8	9	17	16	0.00	0.00	0.00	0.00	0.00	0.00	36	33	10	6	22	21	
7	火	2	2	2	2	2	2	8	8	3	3	6	6	24	30	7	9	17	20	0.00	0.00	0.00	0.00	0.00	0.00	36	33	11	11	24	22	
8	水	3	立下げ	2	立下げ	2	立下げ	8	立下げ	4	立下げ	7	立下げ	24	立下げ	7	立下げ	13	立下げ	0.00	立下げ	0.00	立下げ	0.00	立下げ	36	立下げ	11	立下げ	24	立下げ	
9	木	3		2		2		11		1		7		28		6		15		0.00		0.00		0.00		37		13		27		
10	金	3	立上げ	2	立上げ	3	立上げ	8	立上げ	2	立上げ	5	立上げ	24	立上げ	13	立上げ	19	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	40	立上げ	16	立上げ	26	立上げ	
11	土	3	4	2	2	3	2	8	8	4	6	6	7	23	22	14	9	18	13	0.00	0.00	0.00	0.00	0.00	0.00	38	30	6	4	23	19	
12	日	3	2	2	2	3	2	8	7	2	4	6	6	24	22	9	10	15	15	0.00	0.00	0.00	0.00	0.00	0.00	37	33	3	4	22	20	
13	月	2	2	2	2	2	2	8	8	5	4	7	6	25	26	8	9	15	14	0.00	0.00	0.00	0.00	0.00	0.00	44	35	4	11	24	26	
14	火	3	2	2	1	2	2	12	7	3	3	6	6	26	29	7	11	17	21	0.00	0.00	0.00	0.00	0.00	0.00	33	36	5	6	25	22	
15	水	3	4	2	1	2	2	7	8	3	1	5	5	25	27	12	10	19	20	0.00	0.00	0.00	0.00	0.00	0.00	33	34	5	7	22	20	
16	木	3	3	2	2	2	2	8	7	2	1	5	5	27	29	11	8	20	21	0.00	0.00	0.00	0.00	0.00	0.00	37	29	15	7	23	19	
17	金	立下げ	2	立下げ	2	立下げ	2	立下げ	8	立下げ	2	立下げ	5	立下げ	26	立下げ	8	立下げ	16	立下げ	0.00	立下げ	0.00	立下げ	0.00	立下げ	34	立下げ	10	立下げ	23	
18	土		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ		立下げ	
19	日																															
20	月																															
21	火																															
22	水																															
23	木																															
24	金																															
25	土																															
26	日																															
27	月																															
28	火																															
29	水																															
30	木																															
合計																																
最大		6	4	2	2	3	2	12	9	6	6	7	7	29	30	18	16	22	22	0.00	0.00	0.00	0.00	0.00	0.00	44	36	19	19	28	26	
最小		2	2	1	1	2	2	7	7	0	1	5	4	23	22	6	8	13	13	0.00	0.00	0.00	0.00	0.00	0.00	33	29	3	4	20	19	
平均		3	2	2	2	2	2	8	8	3	3	6	6	26	27	11	10	18	19	0.00	0.00	0.00	0.00	0.00	0.00	37	33	10	9	24	22	
自主規制値		30		ppm		20		ppm		50		ppm		0.01		g/m ³ N		50		ppm												
法規制値		30		ppm		3,500		ppm 相当		430		ppm		0.04		g/m ³ N		250		ppm												

■ 休炉