

# 施設排ガス測定データ

2017年 2月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)							
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均			
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号		
1	水	3	2	2	1	2	2	7	6	2	0	5	3	27	29	12	8	21	24	0.00	0.00	0.00	0.00	0.00	0.00	37	37	6	4	22	23	
2	木	2	3	2	2	2	2	8	5	1	0	4	2	24	29	13	12	19	22	0.00	0.00	0.00	0.00	0.00	0.00	40	38	9	11	23	24	
3	金	2	3	2	2	2	2	7	6	3	1	5	3	27	27	15	12	20	21	0.00	0.00	0.00	0.00	0.00	0.00	35	38	5	8	22	21	
4	土	2	2	2	1	2	2	7	5	2	0	5	2	25	29	13	8	20	20	0.00	0.00	0.00	0.00	0.00	0.00	39	40	5	3	22	18	
5	日	2	2	2	1	2	2	10	5	2	1	5	3	22	29	11	8	17	20	0.00	0.00	0.00	0.00	0.00	0.00	39	39	9	14	24	27	
6	月	2	2	2	2	2	2	8	5	3	2	6	4	22	28	11	14	16	22	0.00	0.00	0.00	0.00	0.00	0.00	37	41	4	4	24	22	
7	火	2	2	2	2	2	2	6	6	1	0	3	2	25	29	10	9	16	19	0.00	0.00	0.00	0.00	0.00	0.00	38	37	4	6	21	21	
8	水	2	2	2	2	2	2	5	3	1	0	3	2	25	28	10	12	16	21	0.00	0.00	0.00	0.00	0.00	0.00	38	35	10	16	26	27	
9	木	2	2	2	2	2	2	8	7	4	3	6	5	26	29	16	21	20	27	0.00	0.00	0.00	0.00	0.00	0.00	36	38	7	9	22	25	
10	金	3	2	2	1	2	2	7	5	1	1	4	3	26	29	7	16	19	22	0.00	0.00	0.00	0.00	0.00	0.00	37	38	5	9	23	23	
11	土	2	2	2	2	2	2	6	4	1	0	3	2	26	27	12	11	18	20	0.00	0.00	0.00	0.00	0.00	0.00	39	41	4	3	21	19	
12	日	2	2	1	1	2	2	6	5	2	2	4	3	24	28	13	13	18	22	0.00	0.00	0.00	0.00	0.00	0.00	38	37	11	5	25	21	
13	月	2	2	2	1	2	2	7	7	1	1	3	3	27	29	9	18	19	24	0.00	0.00	0.00	0.00	0.00	0.00	37	39	4	21	21	29	
14	火	2	4	2	1	2	2	7	9	0	0	3	2	21	28	6	6	13	12	0.00	0.00	0.00	0.00	0.00	0.00	39	35	5	6	21	22	
15	水	2	3	2	2	2	2	6	4	0	0	3	2	27	28	8	10	15	18	0.00	0.00	0.00	0.00	0.00	0.00	37	36	7	5	19	22	
16	木	3	3	2	2	2	2	6	4	1	1	3	2	27	29	14	18	22	24	0.00	0.00	0.00	0.00	0.00	0.00	42	37	7	6	24	23	
17	金	3	3	2	2	2	3	9	6	2	1	5	4	27	32	6	8	20	23	0.00	0.00	0.00	0.00	0.00	0.00	40	36	10	10	22	26	
18	土	3	3	2	2	2	2	6	7	2	1	4	4	23	28	15	19	19	24	0.00	0.00	0.00	0.00	0.00	0.00	40	39	5	6	23	21	
19	日	3	3	2	2	2	2	6	5	2	1	5	3	27	29	14	22	23	26	0.00	0.00	0.00	0.00	0.00	0.00	36	41	8	7	24	24	
20	月	3	3	2	2	2	2	6	5	2	1	4	3	26	29	11	13	20	23	0.00	0.00	0.00	0.00	0.00	0.00	40	42	10	6	24	22	
21	火	3	3	2	2	2	2	6	5	2	0	4	3	29	31	19	20	25	27	0.00	0.00	0.00	0.00	0.00	0.00	35	37	4	9	23	24	
22	水	3	3	2	2	2	2	6	8	2	1	4	3	31	31	21	21	26	27	0.00	0.00	0.00	0.00	0.00	0.00	40	37	11	9	25	22	
23	木	3	3	2	2	2	2	6	4	2	1	3	3	28	29	12	15	21	24	0.00	0.00	0.00	0.00	0.00	0.00	36	34	17	11	28	25	
24	金	2	2	2	1	2	2	5	4	0	0	2	2	28	27	12	9	19	19	0.00	0.00	0.00	0.00	0.00	0.00	41	33	11	16	24	25	
25	土	5	3	2	2	2	2	5	5	1	0	3	2	28	28	12	15	22	22	0.00	0.00	0.00	0.00	0.00	0.00	37	40	8	15	24	27	
26	日	3	3	2	2	2	2	4	3	1	0	2	1	26	32	16	11	20	23	0.00	0.00	0.00	0.00	0.00	0.00	37	36	18	12	28	27	
27	月	3	3	2	2	2	2	7	5	0	0	4	3	28	30	13	14	21	24	0.00	0.00	0.00	0.00	0.00	0.00	36	39	6	7	25	21	
28	火	3	3	2	2	2	2	7	5	0	0	4	3	29	30	13	11	20	21	0.00	0.00	0.00	0.00	0.00	0.00	43	40	3	7	22	23	
合計																																
最大		5	4	2	2	2	3	10	9	4	3	6	5	31	32	21	22	26	27	0.00	0.00	0.00	0.00	0.00	0.00	43	42	18	21	28	29	
最小		2	2	1	1	2	2	4	3	0	0	2	1	21	27	6	6	13	12	0.00	0.00	0.00	0.00	0.00	0.00	35	33	3	3	19	18	
平均		3	3	2	2	2	2	7	5	1	1	4	3	26	29	12	13	19	22	0.00	0.00	0.00	0.00	0.00	0.00	38	38	8	9	23	23	
自主規制値		30		ppm				20		ppm				50		ppm				0.01		g/m <sup>3</sup> N				50		ppm				
法規制値		30		ppm				3,500		ppm 相当				430		ppm				0.04		g/m <sup>3</sup> N				250		ppm				