

# 施設排ガス測定データ

2017年 10月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)							
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均			
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号				
1	日		2		1		2		7		2		5		22		9		17		0.00		0.00		0.00		36		9		26	
2	月	立上げ	2	立上げ	1	立上げ	2	立上げ	7	立上げ	4	立上げ	5	立上げ	22	立上げ	8	立上げ	15	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	37	立上げ	7	立上げ	21	
3	火	3	2	2	1	2	2	6	11	2	2	5	5	16	21	7	4	9	14	0.00	0.00	0.00	0.00	0.00	0.00	19	35	1	5	9	22	
4	水	2	3	2	1	2	2	7	8	2	2	5	5	22	25	12	12	17	18	0.00	0.00	0.00	0.00	0.00	0.00	36	39	1	14	23	25	
5	木	2	3	2	1	2	2	6	11	0	0	3	3	22	25	11	3	16	14	0.00	0.00	0.00	0.00	0.00	0.00	40	43	8	4	21	21	
6	金	2	2	2	1	2	2	8	8	0	2	5	5	22	25	2	10	14	16	0.00	0.00	0.00	0.00	0.00	0.00	35	43	2	13	12	26	
7	土	7	3	2	1	3	2	9	15	1	2	4	6	19	22	10	0	14	10	0.00	0.00	0.00	0.00	0.00	0.00	35	39	2	4	17	26	
8	日	3		2		3		6		1		4		22		9		14		0.00		0.00		0.00		38		2		21		
9	月	3		2		3		7		2		4		22		11		15		0.00		0.00		0.00		38		4		22		
10	火	3		2		2		12		1		3		19		7		12		0.00		0.00		0.00		41		7		19		
11	水	3		2		2		5		0		3		20		2		12		0.00		0.00		0.00		35		2		14		
12	木	3		2		2		7		2		4		22		12		16		0.00		0.00		0.00		46		4		22		
13	金	2		2		2		6		1		4		21		11		15		0.00		0.00		0.00		40		5		25		
14	土	2		2		2		6		1		4		17		8		13		0.00		0.00		0.00		39		6		23		
15	日	2		1		2		7		2		5		31		8		15		0.00		0.00		0.00		41		7		26		
16	月	2		1		2		6		1		4		28		9		20		0.00		0.00		0.00		41		9		23		
17	火	2		2		2		6		1		3		21		10		16		0.00		0.00		0.00		40		7		23		
18	水	3		1		2		7		2		5		27		12		17		0.00		0.00		0.00		37		3		19		
19	木	2		2		2		8		2		4		31		17		24		0.00		0.00		0.00		37		11		25		
20	金	3		2		2		6		2		4		30		15		25		0.00		0.00		0.00		38		8		24		
21	土	2		2		2		7		2		5		27		13		22		0.00		0.00		0.00		37		15		24		
22	日	2		2		2		7		2		4		29		12		22		0.00		0.00		0.00		38		9		26		
23	月	3	立上げ	2	立上げ	2	立上げ	6	立上げ	1	立上げ	3	立上げ	26	立上げ	15	立上げ	21	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	41	立上げ	9	立上げ	27	立上げ	
24	火	2	2	2	1	2	1	6	5	0	2	3	3	28	14	13	6	19	9	0.00	0.00	0.00	0.00	0.00	0.00	36	31	8	5	24	17	
25	水	3	2	2	1	2	1	6	7	0	1	3	4	29	18	13	9	22	12	0.00	0.00	0.00	0.00	0.00	0.00	38	36	4	5	19	16	
26	木	3	2	2	1	2	1	6	7	0	3	4	5	30	22	12	11	21	16	0.00	0.00	0.00	0.00	0.00	0.00	39	38	5	5	26	19	
27	金	3	2	2	1	2	1	7	8	1	2	4	5	28	28	17	10	22	17	0.00	0.00	0.00	0.00	0.00	0.00	40	33	6	6	21	20	
28	土	2	1	2	1	2	1	7	8	1	2	5	5	25	22	11	6	20	14	0.00	0.00	0.00	0.00	0.00	0.00	42	32	6	6	20	20	
29	日	2	1	2	1	2	1	6	9	1	1	4	5	25	25	9	4	19	12	0.00	0.00	0.00	0.00	0.00	0.00	40	36	9	6	23	20	
30	月	2	1	2	1	2	1	6	7	0	0	2	3	28	27	10	6	20	14	0.00	0.00	0.00	0.00	0.00	0.00	40	31	3	5	21	16	
31	火	3	3	2	1	2	2	8	7	1	0	4	4	28	21	13	6	21	13	0.00	0.00	0.00	0.00	0.00	0.00	39	33	7	9	21	20	
合計																																
最大		7	3	2	1	3	2	12	15	2	4	5	6	31	28	17	12	25	18	0.00	0.00	0.00	0.00	0.00	0.00	46	43	15	14	27	26	
最小		2	1	1	1	2	1	5	5	0	0	2	3	16	14	2	0	9	9	0.00	0.00	0.00	0.00	0.00	0.00	19	31	1	4	9	16	
平均		3	2	2	1	2	2	7	8	1	2	4	5	25	23	11	7	18	14	0.00	0.00	0.00	0.00	0.00	0.00	38	36	6	7	21	21	
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m <sup>3</sup> N						50 ppm						
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m <sup>3</sup> N						250 ppm						
※備考	運転計画に基づき 1号炉 10月2日立上げ 2号炉 10月7日立下げ、10月23日立上げ																															
	休炉																															