

施設排ガス測定データ

2017年 11月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	水	2	2	2	1	2	2	7	7	3	3	5	5	28	27	17	15	24	22	0.00	0.00	0.00	0.00	0.00	0.00	40	31	6	8	20	20
2	木	2	2	2	1	2	2	8	6	3	2	5	5	27	23	11	11	22	17	0.00	0.00	0.00	0.00	0.00	0.00	37	38	8	3	24	18
3	金	2	3	2	2	2	2	10	8	2	1	6	5	28	22	5	4	18	13	0.00	0.00	0.00	0.00	0.00	0.00	42	32	7	6	24	20
4	土	7	2	2	1	2	2	11	8	2	2	5	4	28	22	11	9	19	16	0.00	0.00	0.00	0.00	0.00	0.00	37	34	10	5	25	20
5	日	2	2	2	1	2	2	7	6	3	1	5	4	29	27	18	12	25	20	0.00	0.00	0.00	0.00	0.00	0.00	38	32	10	17	24	25
6	月	2	2	2	1	2	2	8	7	4	3	6	5	26	25	13	12	22	18	0.00	0.00	0.00	0.00	0.00	0.00	39	35	6	4	24	20
7	火	2	2	2	1	2	2	7	7	4	2	6	5	27	20	12	10	19	15	0.00	0.00	0.00	0.00	0.00	0.00	43	33	9	8	25	23
8	水	2	2	1	1	2	2	8	9	5	2	7	6	21	25	7	4	14	13	0.00	0.00	0.00	0.00	0.00	0.00	36	37	10	4	24	19
9	木	2	2	1	1	2	2	9	7	4	3	6	5	27	27	9	17	20	21	0.00	0.00	0.00	0.00	0.00	0.00	43	32	8	6	25	23
10	金	2	2	1	1	2	1	6	10	3	0	5	4	25	24	6	6	17	16	0.00	0.00	0.00	0.00	0.00	0.00	36	35	6	3	21	19
11	土	2	2	1	1	2	2	8	7	3	1	6	4	29	31	11	10	21	22	0.00	0.00	0.00	0.00	0.00	0.00	40	31	8	4	23	18
12	日	2	2	1	1	2	2	7	8	1	0	5	4	31	29	8	12	25	24	0.00	0.00	0.00	0.00	0.00	0.00	40	32	5	9	21	23
13	月	2	2	1	1	2	1	6	6	3	1	5	4	30	28	17	14	24	21	0.00	0.00	0.00	0.00	0.00	0.00	39	34	10	13	23	22
14	火	2	2	2	1	2	2	7	7	2	2	6	5	25	27	11	9	19	18	0.00	0.00	0.00	0.00	0.00	0.00	35	37	8	3	23	18
15	水	2	2	2	1	2	2	7	7	1	1	4	3	26	27	12	10	20	16	0.00	0.00	0.00	0.00	0.00	0.00	40	33	9	9	24	19
16	木	3	2	2	2	2	2	8	7	2	1	5	4	29	28	16	11	23	20	0.00	0.00	0.00	0.00	0.00	0.00	41	38	8	13	25	23
17	金	2	2	2	2	2	2	9	7	2	1	5	4	32	29	13	14	23	21	0.00	0.00	0.00	0.00	0.00	0.00	38	27	4	4	19	13
18	土	2	2	2	2	2	2	7	7	2	0	5	4	28	22	10	9	21	16	0.00	0.00	0.00	0.00	0.00	0.00	35	26	6	5	24	16
19	日	2	2	2	1	2	2	5	4	1	0	3	2	30	27	7	9	25	21	0.00	0.00	0.00	0.00	0.00	0.00	41	30	11	4	26	17
20	月	3	2	2	2	2	2	7	7	0	0	5	4	29	28	9	6	22	19	0.00	0.00	0.00	0.00	0.00	0.00	39	32	5	6	21	16
21	火	3	2	2	1	3	2	7	7	1	1	4	4	30	27	11	14	22	21	0.00	0.00	0.00	0.00	0.00	0.00	39	24	11	11	24	18
22	水	3	2	2	1	3	2	6	7	0	0	3	3	27	25	14	10	22	18	0.00	0.00	0.00	0.00	0.00	0.00	38	28	5	4	23	14
23	木	3	2	2	2	2	2	8	7	1	0	4	3	29	27	14	11	22	22	0.00	0.00	0.00	0.00	0.00	0.00	38	29	4	6	25	15
24	金	3	3	2	2	3	2	7	5	1	0	3	3	29	29	15	15	24	24	0.00	0.00	0.00	0.00	0.00	0.00	42	33	12	3	27	19
25	土	3	3	2	2	3	2	4	6	0	0	2	2	26	27	12	6	19	18	0.00	0.00	0.00	0.00	0.00	0.00	33	31	3	6	20	17
26	日	3	2	2	2	3	2	6	6	0	1	4	3	28	25	9	12	22	18	0.00	0.00	0.00	0.00	0.00	0.00	36	27	1	6	24	17
27	月	3	2	2	1	2	2	6	6	1	1	4	4	27	28	13	10	23	21	0.00	0.00	0.00	0.00	0.00	0.00	35	30	8	9	25	19
28	火	3	2	2	2	2	2	7	6	2	2	4	3	27	27	15	15	23	21	0.00	0.00	0.00	0.00	0.00	0.00	36	24	8	9	24	17
29	水	3	2	2	2	2	2	15	11	2	1	6	5	27	25	12	6	22	16	0.00	0.00	0.00	0.00	0.00	0.00	35	23	8	3	24	9
30	木	3	3	2	2	2	2	7	6	1	0	4	2	28	27	9	8	23	19	0.00	0.00	0.00	0.00	0.00	0.00	37	27	5	10	22	16
最大		7	3	2	2	3	2	15	11	5	3	7	6	32	31	18	17	25	24	0.00	0.00	0.00	0.00	0.00	0.00	43	38	12	17	27	25
最小		2	2	1	1	2	1	4	4	0	0	2	2	21	20	5	4	14	13	0.00	0.00	0.00	0.00	0.00	0.00	33	23	1	3	19	9
平均		3	2	2	1	2	2	8	7	2	1	5	4	28	26	12	10	22	19	0.00	0.00	0.00	0.00	0.00	0.00	38	31	7	7	23	18
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考		休炉																													