

# 施設排ガス測定データ

2017年 5月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	月	3	2	2	2	3	2	7	6	2	0	5	4	27	28	8	10	18	22	0.00	0.00	0.00	0.00	0.00	0.00	26	28	7	13	17	20
2	火	3	2	2	1	3	2	8	10	3	3	5	5	24	26	13	14	18	21	0.00	0.00	0.00	0.00	0.00	0.00	38	36	4	11	21	21
3	水	3	9	2	1	3	2	7	12	4	2	6	5	27	26	15	10	22	20	0.00	0.00	0.00	0.00	0.00	0.00	39	41	11	10	26	25
4	木	3	2	3	1	3	2	7	6	3	4	5	5	25	29	12	12	19	22	0.00	0.00	0.00	0.00	0.00	0.00	35	36	6	10	24	25
5	金	3	2	3	1	3	2	8	7	1	3	5	5	22	27	5	11	14	19	0.00	0.00	0.00	0.00	0.00	0.00	37	34	4	5	20	21
6	土	4	2	2	1	3	2	8	7	4	3	6	5	24	26	8	8	16	17	0.00	0.00	0.00	0.00	0.00	0.00	38	37	7	6	24	22
7	日	3	2	2	2	3	2	7	7	3	4	5	5	26	26	12	13	21	20	0.00	0.00	0.00	0.00	0.00	0.00	40	36	4	6	20	22
8	月	4	4	3	2	3	2	8	15	2	4	5	6	28	27	11	14	20	20	0.00	0.00	0.00	0.00	0.00	0.00	38	40	5	8	23	22
9	火	3	2	3	1	3	1	7	7	3	4	6	6	26	26	13	10	19	17	0.00	0.00	0.00	0.00	0.00	0.00	37	35	7	6	22	20
10	水	4	2	3	1	3	1	7	7	2	3	6	6	29	26	7	8	21	17	0.00	0.00	0.00	0.00	0.00	0.00	40	36	5	6	19	24
11	木	3	3	3	1	3	1	10	11	4	3	6	6	27	22	10	0	19	11	0.00	0.00	0.00	0.00	0.00	0.00	40	37	3	4	19	20
12	金	3	2	3	2	3	2	8	7	3	3	6	6	28	27	12	13	21	21	0.00	0.00	0.00	0.00	0.00	0.00	38	38	8	7	24	24
13	土	3	2	3	1	3	2	7	10	4	2	6	5	29	28	13	1	19	13	0.00	0.00	0.00	0.00	0.00	0.00	37	38	4	3	20	17
14	日	4	2	3	1	3	2	8	8	4	2	6	6	23	19	13	3	18	14	0.00	0.00	0.00	0.00	0.00	0.00	37	41	7	5	24	19
15	月	3	2	3	1	3	2	7	8	3	2	5	5	28	25	16	2	21	17	0.00	0.00	0.00	0.00	0.00	0.00	36	35	10	9	25	24
16	火	3	2	2	1	3	2	10	7	1	2	6	5	26	24	14	10	21	17	0.00	0.00	0.00	0.00	0.00	0.00	42	35	5	7	21	20
17	水	3	2	2	2	2	2	7	8	2	1	5	5	29	27	10	11	22	19	0.00	0.00	0.00	0.00	0.00	0.00	35	34	7	3	21	19
18	木	3	2	2	2	2	2	7	7	2	1	4	4	28	25	16	12	23	18	0.00	0.00	0.00	0.00	0.00	0.00	38	35	6	7	25	22
19	金	3	2	2	2	3	2	6	7	1	2	4	4	28	27	8	12	21	21	0.00	0.00	0.00	0.00	0.00	0.00	36	37	9	9	24	22
20	土	3	5	2	2	3	2	7	7	3	3	5	5	29	26	18	10	24	18	0.00	0.00	0.00	0.00	0.00	0.00	37	37	9	6	25	22
21	日	3	2	2	1	2	2	7	11	3	0	4	4	31	21	14	0	20	10	0.00	0.00	0.00	0.00	0.00	0.00	37	39	4	3	19	19
22	月	3	2	2	1	2	2	7	11	2	2	5	5	26	28	9	0	18	16	0.00	0.00	0.00	0.00	0.00	0.00	36	45	8	5	20	20
23	火	3	3	2	1	2	2	7	11	4	0	6	5	27	24	12	1	18	11	0.00	0.00	0.00	0.00	0.00	0.00	36	36	6	5	23	23
24	水	2	2	2	2	2	2	9	7	4	3	6	5	25	29	14	9	18	17	0.00	0.00	0.00	0.00	0.00	0.00	39	36	6	8	24	24
25	木	2	2	2	1	2	2	8	9	4	2	6	6	30	28	14	1	22	18	0.00	0.00	0.00	0.00	0.00	0.00	38	38	4	4	19	21
26	金	3	2	2	1	2	2	8	14	3	0	5	4	25	21	12	0	19	6	0.00	0.00	0.00	0.00	0.00	0.00	37	37	16	3	25	14
27	土	3	2	2	2	2	2	7	6	3	1	5	3	27	19	14	7	20	12	0.00	0.00	0.00	0.00	0.00	0.00	38	38	5	8	23	22
28	日	2	2	2	1	2	2	8	10	2	0	5	4	26	23	12	2	21	12	0.00	0.00	0.00	0.00	0.00	0.00	39	38	5	3	22	19
29	月	2	2	2	2	2	2	8	7	4	1	6	5	22	22	12	7	18	15	0.00	0.00	0.00	0.00	0.00	0.00	36	35	5	6	20	18
30	火	3	2	2	2	2	2	7	7	2	2	5	4	30	24	14	11	21	17	0.00	0.00	0.00	0.00	0.00	0.00	38	36	9	8	22	23
31	水	3	2	2	2	2	2	7	8	0	1	4	4	28	26	5	9	19	21	0.00	0.00	0.00	0.00	0.00	0.00	34	32	5	8	22	24
合計																															
最大		4	9	3	2	3	2	10	15	4	4	6	6	31	29	18	14	24	22	0.00	0.00	0.00	0.00	0.00	0.00	42	45	16	13	26	25
最小		2	2	2	1	2	1	6	6	0	0	4	3	22	19	5	0	14	6	0.00	0.00	0.00	0.00	0.00	0.00	26	28	3	3	17	14
平均		3	2	2	1	3	2	8	9	3	2	5	5	27	25	12	7	20	17	0.00	0.00	0.00	0.00	0.00	0.00	37	37	6	7	22	21
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m <sup>3</sup> N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m <sup>3</sup> N						250 ppm					