

施設排ガス測定データ

2018年 11月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	木	3	13	2	1	2	3	7	11	0	0	4	3	30	29	5	7	18	15	0.00	0.00	0.00	0.00	0.00	0.00	36	30	11	6	26	17
2	金	3	3	2	2	3	2	6	5	2	0	4	3	29	25	15	11	22	18	0.00	0.00	0.00	0.00	0.00	0.00	42	34	9	5	26	22
3	土	3	2	2	2	3	2	8	7	2	1	5	4	30	24	13	14	18	18	0.00	0.00	0.00	0.00	0.00	0.00	35	32	8	17	24	24
4	日	3	2	2	2	3	2	7	7	2	2	4	4	23	26	12	14	19	19	0.00	0.00	0.00	0.00	0.00	0.00	36	35	10	4	25	24
5	月	3	2	2	2	2	2	12	6	1	1	5	4	26	27	10	13	17	19	0.00	0.00	0.00	0.00	0.00	0.00	34	34	9	12	25	24
6	火	3	2	2	2	2	2	7	6	1	2	4	4	30	30	9	13	17	20	0.00	0.00	0.00	0.00	0.00	0.00	37	33	8	11	22	20
7	水	4	6	2	1	2	2	7	8	3	2	5	5	28	31	16	16	24	25	0.00	0.00	0.00	0.00	0.00	0.00	36	30	13	16	26	24
8	木	2	2	2	2	2	2	7	6	3	2	5	3	27	30	17	15	22	24	0.00	0.00	0.00	0.00	0.00	0.00	36	35	12	11	25	24
9	金	2	2	2	1	2	2	8	8	3	3	6	6	25	30	13	13	18	22	0.00	0.00	0.00	0.00	0.00	0.00	39	33	9	7	26	21
10	土	3	3	2	2	2	2	6	6	2	2	4	4	25	30	10	15	17	23	0.00	0.00	0.00	0.00	0.00	0.00	38	32	10	10	23	22
11	日	2	2	2	2	2	2	7	6	1	1	4	3	32	29	14	14	21	24	0.00	0.00	0.00	0.00	0.00	0.00	34	37	11	3	23	21
12	月	2	2	2	1	2	2	8	7	1	2	4	4	29	31	13	17	22	25	0.00	0.00	0.00	0.00	0.00	0.00	41	35	8	12	24	20
13	火	2	2	2	1	2	2	7	5	1	2	4	4	28	30	14	14	21	26	0.00	0.00	0.00	0.00	0.00	0.00	36	34	14	15	24	24
14	水	3	2	2	1	2	2	4	4	0	1	2	2	30	30	14	23	23	26	0.00	0.00	0.00	0.00	0.00	0.00	35	32	12	5	25	22
15	木	2	2	2	1	2	1	7	5	1	1	4	3	28	31	18	21	24	27	0.00	0.00	0.00	0.00	0.00	0.00	39	30	12	7	26	20
16	金	2	2	2	1	2	1	10	4	2	0	4	2	29	31	10	16	21	25	0.00	0.00	0.00	0.00	0.00	0.00	33	29	8	14	23	23
17	土	3	2	2	1	2	2	5	3	2	1	3	2	31	30	9	18	21	26	0.00	0.00	0.00	0.00	0.00	0.00	42	29	10	13	24	22
18	日	2	2	2	1	2	2	6	3	2	1	4	2	31	31	20	19	25	27	0.00	0.00	0.00	0.00	0.00	0.00	35	36	16	10	26	22
19	月	2	2	2	1	2	2	6	8	3	1	5	3	33	32	16	14	25	28	0.00	0.00	0.00	0.00	0.00	0.00	37	35	18	6	27	23
20	火	2	2	2	1	2	1	6	3	0	0	3	2	37	32	16	20	25	28	0.00	0.00	0.00	0.00	0.00	0.00	36	33	17	15	27	25
21	水	8	2	2	1	2	1	6	4	0	0	3	2	31	35	20	23	25	29	0.00	0.00	0.00	0.00	0.00	0.00	38	34	6	4	23	18
22	木	2	2	2	1	2	1	4	3	0	0	2	1	31	31	12	21	25	28	0.00	0.00	0.00	0.00	0.00	0.00	36	31	14	12	24	24
23	金	3	2	2	1	2	2	5	4	0	0	2	1	31	33	19	19	28	27	0.00	0.00	0.00	0.00	0.00	0.00	36	40	5	4	22	21
24	土	3	2	2	1	2	1	4	5	1	1	3	2	34	31	24	23	28	27	0.00	0.00	0.00	0.00	0.00	0.00	36	33	9	5	26	24
25	日	2	2	2	1	2	1	5	4	0	0	3	2	30	30	16	19	26	25	0.00	0.00	0.00	0.00	0.00	0.00	37	34	8	6	24	23
26	月	3	2	2	1	2	1	5	3	1	1	3	2	28	29	15	24	24	27	0.00	0.00	0.00	0.00	0.00	0.00	38	34	6	6	22	23
27	火	3	2	2	1	2	2	8	6	2	1	5	3	30	32	14	17	25	25	0.00	0.00	0.00	0.00	0.00	0.00	38	34	10	5	26	22
28	水	3	2	2	1	2	1	6	5	1	1	4	3	29	29	7	11	24	24	0.00	0.00	0.00	0.00	0.00	0.00	35	38	8	10	25	22
29	木	2	2	2	1	2	2	6	5	2	1	3	3	30	31	18	18	25	27	0.00	0.00	0.00	0.00	0.00	0.00	42	33	10	11	23	24
30	金	3	2	2	1	2	2	8	4	1	0	4	2	31	31	15	20	27	26	0.00	0.00	0.00	0.00	0.00	0.00	39	33	8	13	25	26
最大		8	13	2	2	3	3	12	11	3	3	6	6	37	35	24	24	28	29	0.00	0.00	0.00	0.00	0.00	0.00	42	40	18	17	27	26
最小		2	2	2	1	2	1	4	3	0	0	2	1	23	24	5	7	17	15	0.00	0.00	0.00	0.00	0.00	0.00	33	29	5	3	22	17
平均		3	3	2	1	2	2	7	5	1	1	4	3	30	30	14	17	23	24	0.00	0.00	0.00	0.00	0.00	0.00	37	33	10	9	25	22
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考		休炉																													