

施設排ガス測定データ

2018年 12月	日	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	土	3	2	2	1	2	2	5	4	1	1	3	2	30	30	20	20	26	25	0.00	0.00	0.00	0.00	0.00	0.00	38	39	8	6	25	22
2	日	3	2	2	1	2	2	6	5	1	0	3	2	30	33	19	12	27	27	0.00	0.00	0.00	0.00	0.00	0.00	37	38	9	15	27	26
3	月	3	2	2	1	2	2	8	8	3	2	5	4	30	34	19	11	26	26	0.00	0.00	0.00	0.00	0.00	0.00	37	35	7	7	22	23
4	火	2	2	2	2	2	2	7	5	1	2	4	3	33	30	18	20	24	26	0.00	0.00	0.00	0.00	0.00	0.00	33	34	8	10	22	24
5	水	2	2	2	2	2	2	6	7	1	1	4	3	34	39	17	27	28	29	0.00	0.00	0.00	0.00	0.00	0.00	37	35	6	5	22	20
6	木	3	2	2	2	2	2	7	5	1	0	3	2	39	36	19	19	28	28	0.00	0.00	0.00	0.00	0.00	0.00	37	32	5	3	20	19
7	金	4	2	2	1	2	2	8	5	1	0	4	2	31	32	21	16	27	27	0.00	0.00	0.00	0.00	0.00	0.00	36	34	7	9	24	22
8	土	3	2	2	2	2	2	4	3	0	0	1	1	29	30	19	12	26	26	0.00	0.00	0.00	0.00	0.00	0.00	38	36	8	12	25	25
9	日	3	2	2	1	2	2	4	2	0	0	1	1	31	32	19	26	27	29	0.00	0.00	0.00	0.00	0.00	0.00	33	36	10	6	24	22
10	月	2	2	2	1	2	1	5	3	0	0	2	1	37	39	17	24	27	28	0.00	0.00	0.00	0.00	0.00	0.00	40	37	10	17	25	27
11	火	3	2	2	1	2	1	3	2	0	0	1	1	30	30	9	11	20	23	0.00	0.00	0.00	0.00	0.00	0.00	35	33	4	4	21	20
12	水	3	2	2	1	2	2	4	6	0	0	1	2	26	29	3	10	14	21	0.00	0.00	0.00	0.00	0.00	0.00	38	37	7	5	21	18
13	木	4	2	2	1	3	2	4	4	0	0	1	1	29	31	5	12	15	21	0.00	0.00	0.00	0.00	0.00	0.00	39	35	5	6	22	22
14	金	3	2	2	1	2	2	5	2	1	0	2	1	30	31	14	21	25	27	0.00	0.00	0.00	0.00	0.00	0.00	34	36	7	9	24	23
15	土	2	2	1	1	2	2	6	6	1	1	3	3	29	30	12	15	23	26	0.00	0.00	0.00	0.00	0.00	0.00	35	36	6	4	20	23
16	日	3	2	2	1	2	2	6	5	0	2	4	3	27	30	10	16	22	25	0.00	0.00	0.00	0.00	0.00	0.00	35	36	17	11	26	25
17	月	3	2	2	2	2	2	6	5	0	2	3	4	30	29	7	15	20	24	0.00	0.00	0.00	0.00	0.00	0.00	35	40	7	3	23	22
18	火	4		2		3		7		2		4		32		16		24		0.00		0.00		0.00		43		7		22	
19	水	4		2		3		9		4		5		31		12		25		0.00		0.00		0.00		37		8		23	
20	木	4		2		3		7		2		4		32		11		22		0.00		0.00		0.00		40		10		24	
21	金	3		2		3		6		3		4		33		16		24		0.00		0.00		0.00		30		8		23	
22	土	4		2		3		9		2		4		31		13		24		0.00		0.00		0.00		32		17		27	
23	日	4		2		3		7		2		4		29		11		20		0.00		0.00		0.00		36		14		25	
24	月	4		2		3		7		3		5		31		19		26		0.00		0.00		0.00		36		15		25	
25	火	4		2		3		7		1		3		31		12		24		0.00		0.00		0.00		36		14		24	
26	水	3		2		3		7		2		4		31		21		27		0.00		0.00		0.00		35		15		24	
27	木	3		2		2		15		1		5		45		5		22		0.00		0.00		0.00		35		7		18	
28	金	2		2		2		13		0		3		32		6		18		0.00		0.00		0.00		35		17		25	
29	土	6		2		2		6		1		3		37		12		24		0.00		0.00		0.00		33		19		27	
30	日	2		2		2		7		0		3		27		0		13		0.00		0.00		0.00		40		5		18	
31	月																														
最大		6	2	2	2	3	2	15	8	4	2	5	4	45	39	21	27	28	29	0.00	0.00	0.00	0.00	0.00	0.00	43	40	19	17	27	27
最小		2	2	1	1	2	1	3	2	0	0	1	1	26	29	0	10	13	21	0.00	0.00	0.00	0.00	0.00	0.00	30	32	4	3	18	18
平均		3	2	2	1	2	2	7	5	1	1	3	2	32	32	13	17	23	26	0.00	0.00	0.00	0.00	0.00	0.00	36	36	10	8	23	23
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考	運転管理に基づいて 2号炉 12月17日立下げ 1号炉 12月30日立下げ 休炉																														