

施設排ガス測定データ

2018年 6月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)								
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均				
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号			
1	金	3	3	2	1	2	2	6	6	1	1	4	3	29	29	17	13	24	22	0.00	0.00	0.00	0.00	0.00	0.00	35	37	7	11	23	24		
2	土	2	2	2	1	2	1	7	7	1	2	4	4	30	30	18	15	25	25	0.00	0.00	0.00	0.00	0.00	0.00	41	39	12	8	27	25		
3	日	3	2	2	1	2	1	7	8	3	1	5	5	28	30	16	17	24	25	0.00	0.00	0.00	0.00	0.00	0.00	41	38	11	11	27	25		
4	月	3	2	2	1	2	2	8	7	1	3	4	5	29	31	16	19	23	26	0.00	0.00	0.00	0.00	0.00	0.00	40	40	9	10	25	23		
5	火	3	2	2	1	2	2	8	12	2	1	5	4	29	29	13	9	23	25	0.00	0.00	0.00	0.00	0.00	0.00	40	37	11	12	26	25		
6	水	3	2	2	1	2	2	10	6	3	2	5	3	30	31	11	20	24	26	0.00	0.00	0.00	0.00	0.00	0.00	40	39	10	9	27	24		
7	木	2	2	2	1	2	1	7	7	2	2	5	5	29	29	16	18	22	25	0.00	0.00	0.00	0.00	0.00	0.00	40	41	10	6	25	20		
8	金	2	2	2	1	2	1	6	11	2	3	5	5	27	29	12	1	21	17	0.00	0.00	0.00	0.00	0.00	0.00	44	38	6	10	25	25		
9	土	3	2	2	1	2	1	6	10	0	1	3	4	25	29	1	6	16	19	0.00	0.00	0.00	0.00	0.00	0.00	41	38	3	14	23	23		
10	日	2	2	1	1	2	1	7	5	0	0	4	3	26	29	11	18	18	24	0.00	0.00	0.00	0.00	0.00	0.00	43	37	6	7	23	23		
11	月	2	2	1	1	2	1	7	7	3	2	5	5	23	28	11	17	17	24	0.00	0.00	0.00	0.00	0.00	0.00	40	37	9	13	24	25		
12	火	2	2	1	1	2	1	6	13	1	0	3	3	28	28	12	0	19	17	0.00	0.00	0.00	0.00	0.00	0.00	43	44	8	7	25	21		
13	水	2	1	2	1	2	1	6	6	0	0	3	1	29	28	1	2	22	17	0.00	0.00	0.00	0.00	0.00	0.00	41	34	4	2	20	15		
14	木	2	2	2	1	2	1	6	10	1	0	3	3	30	33	18	12	25	23	0.00	0.00	0.00	0.00	0.00	0.00	41	38	9	10	24	23		
15	金	2	1	2	1	2	1	5	4	1	0	3	2	26	29	9	16	20	22	0.00	0.00	0.00	0.00	0.00	0.00	39	36	9	8	24	22		
16	土	2	3	2	1	2	1	7	6	0	1	4	3	31	28	3	19	23	24	0.00	0.00	0.00	0.00	0.00	0.00	40	39	6	7	22	21		
17	日	2	2	2	1	2	1	5	6	0	1	3	3	28	29	4	16	23	25	0.00	0.00	0.00	0.00	0.00	0.00	41	36	5	9	25	26		
18	月	2	1	2	1	2	1	5	5	0	1	2	3	26	28	8	15	19	21	0.00	0.00	0.00	0.00	0.00	0.00	39	37	4	11	22	24		
19	火	2	2	2	1	2	1	4	6	1	2	2	4	27	28	15	14	22	20	0.00	0.00	0.00	0.00	0.00	0.00	40	39	15	14	27	26		
20	水	2	2	1	0	2	1	5	16	1	1	2	5	29	28	17	1	24	17	0.00	0.00	0.00	0.00	0.00	0.00	40	40	16	6	26	25		
21	木	2	2	1	1	2	1	6	3	1	0	4	1	30	30	18	2	25	19	0.00	0.00	0.00	0.00	0.00	0.00	34	30	12	7	22	15		
22	金		1		1		1		3		0		1		25		3		13		0.00		0.00		0.00		18		4		9		
23	土																																
24	日																																
25	月																																
26	火																																
27	水																																
28	木																																
29	金																																
30	土																																
最大		3	3	2	1	2	2	10	16	3	3	5	5	31	33	18	20	25	26	0.00	0.00	0.00	0.00	0.00	0.00	44	44	16	14	27	26		
最小		2	1	1	0	2	1	4	3	0	0	2	1	23	25	1	0	16	13	0.00	0.00	0.00	0.00	0.00	0.00	34	18	3	2	20	9		
平均		2	2	2	1	2	1	6	7	1	1	4	3	28	29	12	12	22	22	0.00	0.00	0.00	0.00	0.00	0.00	40	37	9	9	24	22		
自主規制値		30				ppm		20				ppm		50				ppm		0.01				g/m ³ N		50				ppm			
法規制値		30				ppm		3,500				ppm 相当		430				ppm		0.04				g/m ³ N		250				ppm			
※ 備考		運転管理に基づいて				1号炉		6月21日立下げ		2号炉		6月22日立下げ																		休炉			
		設備保全に伴い				1号炉		6月12日立下げ		1号炉		6月15日立下げ		2号炉				6月20日立下げ															