

施設排ガス測定データ

2018年 9月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	土	3	2	2	2	2	2	3	2	0	0	2	1	29	20	9	8	21	14	0.00	0.00	0.00	0.00	0.00	0.00	37	33	5	5	18	15
2	日	3	2	2	1	2	2	4	3	1	0	2	1	35	28	17	14	25	20	0.00	0.00	0.00	0.00	0.00	0.00	35	36	6	3	22	15
3	月	2	2	1	1	2	2	3	2	0	0	2	0	23	26	8	8	15	14	0.00	0.00	0.00	0.00	0.00	0.00	33	31	7	6	19	20
4	火	3	2	1	2	2	2	8	5	1	1	4	3	29	28	10	11	24	20	0.00	0.00	0.00	0.00	0.00	0.00	37	38	10	8	25	22
5	水	3	3	2	2	3	2	5	3	0	0	2	1	30	26	18	10	24	16	0.00	0.00	0.00	0.00	0.00	0.00	42	39	11	10	23	25
6	木	3	3	2	1	2	2	4	4	0	0	2	1	30	28	19	12	26	21	0.00	0.00	0.00	0.00	0.00	0.00	35	36	13	16	25	25
7	金	3	2	2	2	3	2	6	7	2	1	4	4	30	28	10	14	25	22	0.00	0.00	0.00	0.00	0.00	0.00	38	33	10	5	23	21
8	土	3	3	2	1	3	2	4	5	0	0	2	2	29	30	8	9	25	22	0.00	0.00	0.00	0.00	0.00	0.00	35	36	8	8	26	25
9	日	3	2	2	1	3	2	4	4	1	1	2	3	30	28	17	19	24	24	0.00	0.00	0.00	0.00	0.00	0.00	37	35	5	4	25	24
10	月	3	2	2	1	3	2	5	4	0	0	2	2	30	29	13	14	25	22	0.00	0.00	0.00	0.00	0.00	0.00	35	39	7	13	22	25
11	火	3	2	2	1	2	2	1	2	0	0	0	0	29	29	13	9	23	20	0.00	0.00	0.00	0.00	0.00	0.00	37	34	6	7	19	22
12	水	3	2	2	1	2	2	6	5	0	0	2	2	30	29	12	12	25	21	0.00	0.00	0.00	0.00	0.00	0.00	40	38	6	10	23	23
13	木	3	2	2	1	3	2	8	7	1	0	3	3	30	29	20	12	26	21	0.00	0.00	0.00	0.00	0.00	0.00	35	34	6	5	21	22
14	金	3	2	2	1	3	2	7	6	1	2	4	4	29	29	13	16	21	23	0.00	0.00	0.00	0.00	0.00	0.00	32	33	7	13	20	24
15	土	4		3		3		10		1		6		27		5		19		0.00		0.00		0.00		36		6		22	
16	日	4		2		3		10		5		8		30		14		23		0.00		0.00		0.00		38		4		21	
17	月	4		2		3		8		2		5		28		15		21		0.00		0.00		0.00		39		7		22	
18	火	3		2		3		12		2		4		30		10		23		0.00		0.00		0.00		35		7		18	
19	水	5		2		3		6		0		4		34		2		25		0.00		0.00		0.00		36		6		22	
20	木	3		2		2		6		3		4		30		19		27		0.00		0.00		0.00		37		8		20	
21	金	3		2		3		13		1		4		30		7		24		0.00		0.00		0.00		42		6		22	
22	土	3		2		3		6		1		4		31		6		26		0.00		0.00		0.00		38		6		23	
23	日	4		2		3		7		3		4		30		21		27		0.00		0.00		0.00		36		9		24	
24	月	4		2		3		7		0		3		29		11		23		0.00		0.00		0.00		38		6		23	
25	火	4		2		3		5		1		3		30		15		24		0.00		0.00		0.00		37		12		24	
26	水	3		2		2		7		0		3		36		8		24		0.00		0.00		0.00		37		9		20	
27	木	3		2		2		3		0		1		31		14		26		0.00		0.00		0.00		36		10		24	
28	金	3		2		2		4		0		2		29		19		24		0.00		0.00		0.00		39		9		24	
29	土	3		2		2		5		1		3		32		16		26		0.00		0.00		0.00		37		13		26	
30	日	3		2		3		5		1		3		29		10		24		0.00		0.00		0.00		39		11		23	
最大		5	3	3	2	3	2	13	7	5	2	8	4	36	30	21	19	27	24	0.00	0.00	0.00	0.00	0.00	0.00	42	39	13	16	26	25
最小		2	2	1	1	2	2	1	2	0	0	0	0	23	20	2	8	15	14	0.00	0.00	0.00	0.00	0.00	0.00	32	31	4	3	18	15
平均		3	2	2	1	3	2	6	4	1	0	3	2	30	28	13	12	24	20	0.00	0.00	0.00	0.00	0.00	0.00	37	35	8	8	22	22
自主規制値		30				ppm		20				ppm		50				ppm		0.01				g/m ³ N		50				ppm	
法規制値		30				ppm		3,500				ppm 相当		430				ppm		0.04				g/m ³ N		250				ppm	
※ 備考	運転管理に基づき 2号炉 9月14日立下げ																									休炉					