

# 施設排ガス測定データ

2019年 1月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)								
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均				
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号			
1	火																																
2	水																																
3	木																																
4	金		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ				
5	土		2		1		2		5		0		2		17		5		9		0.00		0.00		0.00		38		5		19		
6	日		1		1		1		1		0		0		9		3		6		0.00		0.00		0.00		30		17		22		
7	月		2		1		1		1		0		0		6		2		4		0.00		0.00		0.00		33		13		24		
8	火		2		1		1		5		0		2		14		3		7		0.00		0.00		0.00		32		5		21		
9	水		2		1		1		3		0		1		12		4		7		0.00		0.00		0.00		33		15		23		
10	木		2		1		1		5		0		2		24		5		11		0.00		0.00		0.00		35		8		24		
11	金		2		2		2		8		3		6		29		16		23		0.00		0.00		0.00		35		14		23		
12	土		2		1		2		6		2		4		29		16		24		0.00		0.00		0.00		36		12		25		
13	日		3		1		2		4		1		3		29		15		24		0.00		0.00		0.00		32		9		24		
14	月		3		1		2		7		2		4		30		16		24		0.00		0.00		0.00		36		11		24		
15	火		2		1		2		5		2		4		30		15		24		0.00		0.00		0.00		33		14		26		
16	水		3		2		2		6		1		4		30		16		26		0.00		0.00		0.00		35		13		24		
17	木		3		2		2		8		4		6		30		13		22		0.00		0.00		0.00		38		12		25		
18	金		3		2		2		7		2		4		34		17		26		0.00		0.00		0.00		34		10		24		
19	土		3		2		2		5		1		3		30		16		25		0.00		0.00		0.00		33		5		22		
20	日		3		2		2		7		3		5		30		16		24		0.00		0.00		0.00		31		11		25		
21	月	立上げ	3	立上げ	2	立上げ	2	立上げ	6	立上げ	1	立上げ	4	立上げ	28	立上げ	13	立上げ	21	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	32	立上げ	12	立上げ	24
22	火	3	4	2	2	2	2	6	6	0	2	5	4	27	30	0	16	15	23	0.00	0.00	0.00	0.00	0.00	0.00	32	38	5	6	17	23		
23	水	3	3	2	1	3	2	6	7	1	1	4	4	30	29	13	11	22	22	0.00	0.00	0.00	0.00	0.00	0.00	33	34	18	18	26	26		
24	木	3	5	2	2	3	2	6	6	1	2	3	4	29	30	15	16	22	23	0.00	0.00	0.00	0.00	0.00	0.00	34	31	8	18	19	25		
25	金	3	3	2	2	3	2	5	5	0	1	3	3	30	30	14	16	24	25	0.00	0.00	0.00	0.00	0.00	0.00	36	33	12	11	23	23		
26	土	3	3	2	2	3	2	8	7	3	3	5	5	31	30	17	23	26	28	0.00	0.00	0.00	0.00	0.00	0.00	39	36	9	13	23	25		
27	日	3	2	2	2	2	2	7	7	1	1	3	3	31	31	18	20	27	26	0.00	0.00	0.00	0.00	0.00	0.00	36	35	12	13	25	26		
28	月	3	2	2	2	2	2	6	5	1	1	4	3	37	29	13	14	25	24	0.00	0.00	0.00	0.00	0.00	0.00	33	35	8	10	23	24		
29	火	3	2	2	2	2	2	5	7	1	1	4	4	31	29	17	18	25	24	0.00	0.00	0.00	0.00	0.00	0.00	33	32	15	10	25	24		
30	水	2	3	2	2	2	2	7	6	2	1	4	4	31	28	19	12	26	22	0.00	0.00	0.00	0.00	0.00	0.00	38	38	7	9	23	26		
31	木	4	3	2	2	3	2	6	6	1	1	3	3	29	28	17	11	23	18	0.00	0.00	0.00	0.00	0.00	0.00	36	36	11	7	24	23		
最大		4	5	2	2	3	2	8	8	3	4	5	6	37	34	19	23	27	28	0.00	0.00	0.00	0.00	0.00	0.00	39	38	18	18	26	26		
最小		2	1	2	1	2	1	5	1	0	0	3	0	27	6	0	2	15	4	0.00	0.00	0.00	0.00	0.00	0.00	32	30	5	5	17	19		
平均		3	3	2	2	3	2	6	6	1	1	4	3	31	26	14	13	24	20	0.00	0.00	0.00	0.00	0.00	0.00	35	34	11	11	23	24		
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m <sup>3</sup> N						50 ppm							
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m <sup>3</sup> N						250 ppm							
※ 備考	運転管理に基づき 2号炉 1月4日立上げ 1号炉 1月21日立上げ <span style="background-color: #cccccc; padding: 2px;">休炉</span>																																