

施設排ガス測定データ

2019年 3月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	金	3	2	2	1	2	2	7	6	1	0	3	2	32	27	14	3	25	19	0.00	0.00	0.00	0.00	0.00	0.00	39	40	7	4	23	26
2	土	3	2	2	1	2	2	6	4	1	0	2	1	29	28	16	11	25	20	0.00	0.00	0.00	0.00	0.00	0.00	36	36	13	19	25	29
3	日	3	2	2	1	2	2	7	6	1	1	4	3	31	29	21	18	27	24	0.00	0.00	0.00	0.00	0.00	0.00	36	38	7	15	22	27
4	月	3	2	2	1	2	2	6	5	1	0	3	2	30	31	22	3	27	22	0.00	0.00	0.00	0.00	0.00	0.00	35	41	15	4	25	22
5	火	3	2	2	2	2	2	4	4	0	0	2	2	32	29	22	17	28	23	0.00	0.00	0.00	0.00	0.00	0.00	37	38	8	10	22	25
6	水	3	2	2	2	3	2	6	7	1	0	4	3	32	31	16	13	28	24	0.00	0.00	0.00	0.00	0.00	0.00	36	34	6	12	22	26
7	木	3	2	2	2	3	2	6	6	0	1	3	4	30	30	9	19	25	26	0.00	0.00	0.00	0.00	0.00	0.00	36	39	5	7	23	21
8	金	3	2	2	1	3	2	5	4	1	0	3	2	32	30	18	17	27	25	0.00	0.00	0.00	0.00	0.00	0.00	39	32	9	7	23	19
9	土	3	2	2	1	3	2	7	6	1	1	5	5	31	35	12	17	27	27	0.00	0.00	0.00	0.00	0.00	0.00	41	31	12	8	26	22
10	日	3	2	2	1	3	2	4	4	0	0	3	2	30	28	18	12	26	20	0.00	0.00	0.00	0.00	0.00	0.00	36	31	8	9	22	19
11	月	3	2	2	1	3	2	3	4	0	1	2	3	30	29	15	14	27	24	0.00	0.00	0.00	0.00	0.00	0.00	36	29	5	13	24	22
12	火	3	2	3	1	3	2	5	5	0	0	2	2	31	30	19	12	26	22	0.00	0.00	0.00	0.00	0.00	0.00	31	30	12	16	24	22
13	水	4	2	3	1	3	2	5	4	0	0	2	2	27	27	14	12	24	21	0.00	0.00	0.00	0.00	0.00	0.00	35	30	7	7	22	20
14	木	3	2	2	1	3	2	4	4	0	0	1	1	30	31	12	20	27	26	0.00	0.00	0.00	0.00	0.00	0.00	38	28	7	15	23	21
15	金	3	3	2	1	3	2	6	6	1	0	4	3	30	30	18	13	26	24	0.00	0.00	0.00	0.00	0.00	0.00	36	28	7	13	22	20
16	土	3	2	2	1	2	2	6	6	1	2	4	4	32	29	13	14	26	25	0.00	0.00	0.00	0.00	0.00	0.00	39	30	12	13	27	23
17	日	3	2	2	1	2	2	6	6	1	2	3	4	32	30	22	20	28	26	0.00	0.00	0.00	0.00	0.00	0.00	34	30	11	16	23	24
18	月	3	2	2	1	2	2	6	7	0	2	4	4	31	36	11	16	26	27	0.00	0.00	0.00	0.00	0.00	0.00	38	30	16	4	27	18
19	火	3	2	2	2	2	2	10	6	2	3	4	4	38	34	18	21	27	26	0.00	0.00	0.00	0.00	0.00	0.00	38	29	17	16	26	21
20	水	3	6	2	2	2	2	6	7	2	2	4	4	38	34	21	18	28	26	0.00	0.00	0.00	0.00	0.00	0.00	37	26	8	10	25	20
21	木	3	2	2	2	2	2	8	7	3	3	5	5	31	29	20	9	26	20	0.00	0.00	0.00	0.00	0.00	0.00	38	26	8	6	23	14
22	金	2	2	2	2	2	2	6	6	1	1	4	3	28	25	13	10	21	18	0.00	0.00	0.00	0.00	0.00	0.00	39	27	11	12	25	20
23	土	2	2	2	1	2	2	4	5	0	1	2	2	25	24	9	12	18	17	0.00	0.00	0.00	0.00	0.00	0.00	40	32	6	11	24	25
24	日	3	2	2	1	2	1	7	6	0	2	5	4	28	26	6	17	23	21	0.00	0.00	0.00	0.00	0.00	0.00	38	28	8	9	25	20
25	月	3		2		2		5		2		4		32		18		25		0.00		0.00		0.00		37		13		25	
26	火	3		2		2		8		2		4		29		18		25		0.00		0.00		0.00		37		9		27	
27	水	3		2		2		6		1		4		30		16		25		0.00		0.00		0.00		38		10		24	
28	木	3		2		2		6		3		5		31		13		26		0.00		0.00		0.00		38		6		24	
29	金	3		2		3		13		2		4		32		19		26		0.00		0.00		0.00		37		9		23	
30	土	3		2		2		7		3		5		31		16		25		0.00		0.00		0.00		37		8		24	
31	日	3		2		3		6		2		4		29		16		24		0.00		0.00		0.00		33		13		26	
最大		4	6	3	2	3	2	13	7	3	3	5	5	38	36	22	21	28	27	0.00	0.00	0.00	0.00	0.00	0.00	41	41	17	19	27	29
最小		2	2	2	1	2	1	3	4	0	0	1	1	25	24	6	3	18	17	0.00	0.00	0.00	0.00	0.00	0.00	31	26	5	4	22	14
平均		3	2	2	1	2	2	6	5	1	1	3	3	31	30	16	14	26	23	0.00	0.00	0.00	0.00	0.00	0.00	37	32	9	11	24	22
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考	運転管理基づき 2号炉 3月24日立下げ 休炉																														