

施設排ガス測定データ

2019年 10月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	火	1	2	1	1	1	2	7	7	6	1	7	4	19	23	16	8	18	16	0.00	0.00	0.00	0.00	0.00	0.00	17	37	10	6	14	20
2	水	1	2	1	2	1	2	7	6	1	2	5	4	26	29	9	13	19	23	0.00	0.00	0.00	0.00	0.00	0.00	35	34	10	11	22	22
3	木	1	2	1	2	1	2	7	7	0	1	4	3	27	26	9	9	18	16	0.00	0.00	0.00	0.00	0.00	0.00	32	32	8	5	23	19
4	金	2	2	1	1	1	2	8	7	1	2	4	3	26	26	9	13	19	19	0.00	0.00	0.00	0.00	0.00	0.00	41	33	6	5	20	21
5	土	1	6	1	1	1	2	7	3	1	1	3	2	26	23	14	11	19	17	0.00	0.00	0.00	0.00	0.00	0.00	37	33	8	4	23	19
6	日	1	2	1	1	1	2	6	5	2	1	4	3	28	28	16	16	23	22	0.00	0.00	0.00	0.00	0.00	0.00	35	31	9	5	24	22
7	月	1	2	0	1	1	2	7	5	1	2	4	3	30	29	4	12	20	22	0.00	0.00	0.00	0.00	0.00	0.00	39	34	4	6	20	20
8	火	1	2	0	1	1	1	7	4	1	1	3	2	22	21	11	9	16	14	0.00	0.00	0.00	0.00	0.00	0.00	38	25	5	8	20	18
9	水	1	2	0	1	1	1	6	5	0	1	2	2	28	22	10	12	16	16	0.00	0.00	0.00	0.00	0.00	0.00	40	37	9	4	23	21
10	木	1	2	1	1	1	1	7	7	0	2	3	5	25	27	2	16	17	19	0.00	0.00	0.00	0.00	0.00	0.00	39	36	5	2	20	21
11	金	1	2	1	1	1	2	5	5	0	1	2	3	25	24	8	11	17	17	0.00	0.00	0.00	0.00	0.00	0.00	39	32	7	4	24	17
12	土	1		0		1		7		0		2		22		11		16		0.00		0.00		0.00		39		11		25	
13	日	1		0		1		7		3		5		27		13		22		0.00		0.00		0.00		34		7		24	
14	月	1		0		1		4		1		2		25		14		19		0.00		0.00		0.00		38		13		25	
15	火	1		1		1		5		0		2		29		14		21		0.00		0.00		0.00		39		11		25	
16	水	1		1		1		6		2		4		29		13		19		0.00		0.00		0.00		35		7		24	
17	木	1		1		1		8		0		4		25		10		19		0.00		0.00		0.00		40		15		26	
18	金	1		1		1		5		1		3		27		14		22		0.00		0.00		0.00		35		15		24	
19	土	1		1		1		8		0		2		27		0		18		0.00		0.00		0.00		38		8		23	
20	日	1		1		1		5		0		2		28		19		24		0.00		0.00		0.00		35		15		28	
21	月	1		1		1		6		1		3		26		8		21		0.00		0.00		0.00		36		12		25	
22	火	1		1		1		8		1		5		28		15		23		0.00		0.00		0.00		36		13		24	
23	水	1		0		1		7		0		4		29		6		20		0.00		0.00		0.00		34		11		25	
24	木	1		0		1		5		0		3		30		15		22		0.00		0.00		0.00		35		11		25	
25	金	1		1		1		5		2		4		31		23		27		0.00		0.00		0.00		37		12		24	
26	土	1		1		1		5		1		3		31		11		24		0.00		0.00		0.00		36		17		27	
27	日	1		0		1		3		0		2		28		9		21		0.00		0.00		0.00		35		10		23	
28	月	1		0		1		4		1		3		27		12		21		0.00		0.00		0.00		33		9		23	
29	火	1		0		1		6		1		3		28		16		22		0.00		0.00		0.00		34		17		26	
30	水	1		1		1		5		0		2		29		10		23		0.00		0.00		0.00		34		8		24	
31	木	2		0		1		6		0		3		28		8		22		0.00		0.00		0.00		33		10		26	
最大		2	6	1	2	1	2	8	7	6	2	7	5	31	29	23	16	27	23	0.00	0.00	0.00	0.00	0.00	0.00	41	37	17	11	28	22
最小		1	2	0	1	1	1	3	3	0	1	2	2	19	21	0	8	16	14	0.00	0.00	0.00	0.00	0.00	0.00	17	25	4	2	14	17
平均		1	2	1	1	1	2	6	6	1	1	3	3	27	25	11	12	20	18	0.00	0.00	0.00	0.00	0.00	0.00	36	33	10	5	24	20
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考	運転管理に基づき 1号炉 10月1日立上げ 2号炉 10月11日立下げ 休炉																														