

施設排ガス測定データ

2019年 4月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	月	3		2		3		7		1		3		31		4		23		0.00		0.00		0.00		35		7		24		
2	火	3		2		3		7		3		5		31		16		25		0.00		0.00		0.00		34		13		25		
3	水	3		2		3		6		1		3		32		15		27		0.00		0.00		0.00		37		9		24		
4	木	3		2		3		5		1		3		29		18		24		0.00		0.00		0.00		36		14		26		
5	金	3		2		3		6		1		4		28		17		23		0.00		0.00		0.00		33		11		22		
6	土	3		2		2		7		3		5		30		8		21		0.00		0.00		0.00		36		11		24		
7	日	3		2		2		7		4		6		30		17		26		0.00		0.00		0.00		36		11		25		
8	月	4		2		3		8		5		6		27		11		20		0.00		0.00		0.00		36		16		27		
9	火	3		2		3		7		2		5		29		11		23		0.00		0.00		0.00		38		17		27		
10	水	2		2		2		7		1		5		31		3		23		0.00		0.00		0.00		39		9		28		
11	木	2		2		2		9		2		6		30		13		25		0.00		0.00		0.00		36		10		26		
12	金	2	立上げ	2	立上げ	2	立上げ	8	立上げ	2	立上げ	5	立上げ	31	立上げ	15	立上げ	25	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	37	立上げ	16	立上げ	26	立上げ	
13	土	2	2	2	1	2	2	6	7	1	5	4	7	34	24	12	12	27	20	0.00	0.00	0.00	0.00	0.00	0.00	40	38	14	6	24	18	
14	日	2	2	1	1	2	1	8	9	3	5	7	7	37	29	21	8	28	18	0.00	0.00	0.00	0.00	0.00	0.00	36	27	14	4	25	16	
15	月	2	2	2	1	2	1	6	8	2	3	4	6	37	26	22	12	28	19	0.00	0.00	0.00	0.00	0.00	0.00	36	30	12	12	23	19	
16	火	3	2	2	1	2	1	6	8	1	1	3	4	31	29	17	11	26	21	0.00	0.00	0.00	0.00	0.00	0.00	35	29	10	8	24	18	
17	水	3	2	2	1	2	1	7	9	3	4	5	6	41	30	25	16	30	23	0.00	0.00	0.00	0.00	0.00	0.00	32	22	6	3	20	9	
18	木	3	2	2	1	2	2	6	8	2	3	4	5	31	28	22	14	28	20	0.00	0.00	0.00	0.00	0.00	0.00	38	33	12	3	24	17	
19	金	3	2	2	1	3	2	5	7	2	2	3	4	33	34	19	14	28	22	0.00	0.00	0.00	0.00	0.00	0.00	33	29	12	8	24	16	
20	土	3	2	2	1	2	2	6	8	2	3	4	5	31	27	18	11	26	19	0.00	0.00	0.00	0.00	0.00	0.00	30	27	21	7	26	18	
21	日		2		1		2		8		5		7		22		11		16		0.00		0.00		0.00		24		10		18	
22	月		2		1		1		7		3		6		25		13		18		0.00		0.00		0.00		28		8		16	
23	火		2		1		2		9		3		6		22		9		15		0.00		0.00		0.00		25		4		17	
24	水		2		1		2		7		5		6		19		8		13		0.00		0.00		0.00		26		14		21	
25	木		2		1		2		7		5		6		27		10		18		0.00		0.00		0.00		30		6		19	
26	金		2		1		2		9		5		7		16		8		11		0.00		0.00		0.00		28		9		20	
27	土		2		1		1		8		4		6		24		9		15		0.00		0.00		0.00		30		16		23	
28	日		1		1		1		7		4		6		20		10		16		0.00		0.00		0.00		28		13		17	
29	月		1		1		1		8		5		7		25		13		18		0.00		0.00		0.00		29		8		20	
30	火		2		1		1		8		5		7		21		10		15		0.00		0.00		0.00		23		15		20	
最大		4	2	2	1	3	2	9	9	5	5	7	7	41	34	25	16	30	23	0.00	0.00	0.00	0.00	0.00	0.00	40	38	21	16	28	23	
最小		2	1	1	1	2	1	5	7	1	1	3	4	27	16	3	8	20	11	0.00	0.00	0.00	0.00	0.00	0.00	30	22	6	3	20	9	
平均		3	2	2	1	2	2	7	8	2	4	5	6	32	25	15	11	25	18	0.00	0.00	0.00	0.00	0.00	0.00	36	28	12	9	25	18	
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm						
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm						
※ 備考	運転管理に基づき 2号炉 4月12日立上げ 1号炉 4月20日立下げ 休炉																															