

施設排ガス測定データ

2019年 5月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)							
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均			
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号		
1	水		2		1		1		7		1		5		20		0		10		0.00		0.00		0.00		33		10		18		
2	木		2		1		2		2		0		1		2		0		0		0.00		0.00		0.00		28		4		19		
3	金		2		1		2		1		0		1		4		0		2		0.00		0.00		0.00		30		12		22		
4	土		2		1		2		1		0		0		4		1		2		0.00		0.00		0.00		35		5		22		
5	日		2		1		2		1		0		0		4		1		2		0.00		0.00		0.00		28		5		21		
6	月		2		2		2		1		0		1		2		1		1		0.00		0.00		0.00		32		14		22		
7	火	立上げ	2	立上げ	1	立上げ	2	立上げ	0	立上げ	0	立上げ	0	立上げ	1	立上げ	0	立上げ	0	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	30	立上げ	18	立上げ	23
8	水	3	2	2	1	2	2	3	0	0	0	0	0	6	1	2	0	4	0	0.00	0.00	0.00	0.00	0.00	0.00	36	25	6	4	20	14		
9	木	3	2	2	1	2	2	2	2	0	0	1	1	5	2	1	0	3	1	0.00	0.00	0.00	0.00	0.00	0.00	33	31	9	3	20	12		
10	金	3	2	2	2	2	2	7	8	1	1	2	3	23	21	0	1	4	6	0.00	0.00	0.00	0.00	0.00	0.00	34	31	9	11	25	23		
11	土	2	2	2	2	2	2	8	8	4	5	6	7	22	23	13	13	16	18	0.00	0.00	0.00	0.00	0.00	0.00	36	33	21	12	27	22		
12	日	3	2	2	2	2	2	8	8	3	4	6	6	22	21	5	12	16	16	0.00	0.00	0.00	0.00	0.00	0.00	37	29	10	13	22	23		
13	月	3	2	2	2	2	2	7	7	4	5	6	7	20	21	7	10	15	16	0.00	0.00	0.00	0.00	0.00	0.00	35	31	15	13	26	23		
14	火	2	2	2	2	2	2	8	8	4	6	7	7	19	18	5	7	12	14	0.00	0.00	0.00	0.00	0.00	0.00	37	33	11	7	23	20		
15	水	2	2	2	2	2	2	11	8	6	6	7	7	19	21	11	11	14	16	0.00	0.00	0.00	0.00	0.00	0.00	32	29	12	13	23	20		
16	木	2	2	2	2	2	2	8	7	4	4	7	6	22	22	7	9	16	14	0.00	0.00	0.00	0.00	0.00	0.00	35	29	13	16	24	22		
17	金	2	2	2	1	2	2	7	7	4	4	6	7	27	26	10	12	20	18	0.00	0.00	0.00	0.00	0.00	0.00	33	33	13	17	25	23		
18	土	2	3	2	2	2	2	9	9	4	4	6	6	28	24	15	13	21	17	0.00	0.00	0.00	0.00	0.00	0.00	36	32	9	12	25	21		
19	日	2	2	2	2	2	2	8	7	4	4	7	6	26	23	12	13	18	17	0.00	0.00	0.00	0.00	0.00	0.00	33	32	15	8	25	22		
20	月	2	2	2	2	2	2	8	8	5	4	7	7	39	25	10	10	17	16	0.00	0.00	0.00	0.00	0.00	0.00	37	33	11	8	23	21		
21	火	2	2	2	2	2	2	8	8	5	3	7	7	26	24	10	5	16	15	0.00	0.00	0.00	0.00	0.00	0.00	37	33	13	17	25	23		
22	水	2	7	2	2	2	2	8	14	3	1	5	5	30	26	16	5	25	16	0.00	0.00	0.00	0.00	0.00	0.00	36	31	16	4	26	18		
23	木	2	2	2	2	2	2	8	7	3	3	6	6	29	26	14	14	23	18	0.00	0.00	0.00	0.00	0.00	0.00	36	31	8	12	24	21		
24	金	2	2	2	2	2	2	8	8	5	4	6	6	30	27	16	14	24	20	0.00	0.00	0.00	0.00	0.00	0.00	33	35	15	11	27	24		
25	土	3	3	2	2	2	2	7	7	4	4	6	6	29	29	17	13	25	21	0.00	0.00	0.00	0.00	0.00	0.00	34	32	17	11	27	24		
26	日	3	2	2	2	2	2	8	7	6	4	7	7	29	18	14	8	24	13	0.00	0.00	0.00	0.00	0.00	0.00	35	32	11	8	25	21		
27	月	3	2	2	2	2	2	7	7	5	3	6	6	30	22	18	11	24	15	0.00	0.00	0.00	0.00	0.00	0.00	33	30	10	13	23	22		
28	火	2	10	2	2	2	2	13	12	5	3	7	7	29	19	9	6	21	13	0.00	0.00	0.00	0.00	0.00	0.00	35	31	7	16	22	22		
29	水	2	2	2	2	2	2	8	7	5	3	6	6	29	23	14	3	21	14	0.00	0.00	0.00	0.00	0.00	0.00	32	28	10	10	24	19		
30	木	2	6	2	2	2	2	8	9	3	2	5	6	30	23	19	12	27	18	0.00	0.00	0.00	0.00	0.00	0.00	31	30	10	8	23	17		
31	金	2	2	2	2	2	2	8	7	5	4	6	6	29	25	11	11	23	18	0.00	0.00	0.00	0.00	0.00	0.00	34	29	6	17	23	23		
最大		3	10	2	2	2	2	13	14	6	6	7	7	39	29	19	14	27	21	0.00	0.00	0.00	0.00	0.00	0.00	37	35	21	18	27	24		
最小		2	2	2	1	2	1	2	0	0	0	0	0	5	1	0	0	3	0	0.00	0.00	0.00	0.00	0.00	0.00	31	25	6	3	20	12		
平均		2	3	2	2	2	2	8	6	4	3	6	5	25	18	11	7	18	12	0.00	0.00	0.00	0.00	0.00	0.00	35	31	12	11	24	21		
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm							
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm							
※ 備考	運転管理に基づき 1号炉 5月7日立上げ 休炉																																