

施設排ガス測定データ

2019年 6月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	土	2	2	2	2	2	2	8	8	5	2	7	6	26	21	8	2	17	10	0.00	0.00	0.00	0.00	0.00	0.00	35	29	16	5	27	19
2	日	2	2	2	2	2	2	8	8	5	5	7	7	31	21	14	11	23	14	0.00	0.00	0.00	0.00	0.00	0.00	34	34	16	9	26	22
3	月	2	3	2	2	2	2	8	8	5	5	7	7	31	27	14	10	24	19	0.00	0.00	0.00	0.00	0.00	0.00	36	32	8	13	24	23
4	火	3	3	2	2	2	2	8	8	6	4	7	7	26	24	13	1	19	14	0.00	0.00	0.00	0.00	0.00	0.00	33	32	11	6	25	21
5	水	3	3	2	2	2	2	9	8	6	4	7	7	24	24	13	5	19	15	0.00	0.00	0.00	0.00	0.00	0.00	36	34	11	6	25	16
6	木	3	3	2	2	2	2	7	7	4	5	6	6	28	27	14	13	19	18	0.00	0.00	0.00	0.00	0.00	0.00	39	36	8	13	25	23
7	金	3	2	2	2	2	2	8	8	4	5	7	6	24	23	6	4	15	12	0.00	0.00	0.00	0.00	0.00	0.00	35	33	7	10	24	20
8	土	3	2	2	2	2	2	8	7	4	4	6	6	29	13	14	7	21	10	0.00	0.00	0.00	0.00	0.00	0.00	35	28	16	13	24	23
9	日	2	4	2	2	2	2	8	10	3	2	6	6	24	16	7	3	18	9	0.00	0.00	0.00	0.00	0.00	0.00	38	35	11	11	23	19
10	月	3	2	2	2	2	2	8	8	5	0	7	5	21	17	9	6	14	10	0.00	0.00	0.00	0.00	0.00	0.00	40	31	11	5	25	18
11	火	2	2	2	1	2	2	7	5	1	0	5	2	25	22	8	4	15	10	0.00	0.00	0.00	0.00	0.00	0.00	31	24	12	8	21	17
12	水	3	2	2	1	2	2	5	5	1	0	3	3	28	27	14	9	22	19	0.00	0.00	0.00	0.00	0.00	0.00	34	32	12	7	24	20
13	木	3	2	2	1	2	2	7	7	1	0	4	3	30	26	15	6	24	18	0.00	0.00	0.00	0.00	0.00	0.00	32	31	10	5	23	19
14	金	3	2	2	1	2	2	7	5	1	0	3	2	32	28	14	10	23	17	0.00	0.00	0.00	0.00	0.00	0.00	32	34	14	13	25	21
15	土	3	2	2	1	2	1	8	5	1	1	3	3	26	26	12	12	21	19	0.00	0.00	0.00	0.00	0.00	0.00	32	28	9	9	22	21
16	日	3	2	2	1	2	2	8	7	1	3	5	5	29	29	17	10	24	23	0.00	0.00	0.00	0.00	0.00	0.00	33	31	18	7	26	22
17	月	3	2	2	1	2	2	6	7	0	0	4	4	28	29	11	8	20	22	0.00	0.00	0.00	0.00	0.00	0.00	37	31	16	8	25	19
18	火	3		2		2		6		1		3		24		9		17		0.00		0.00		0.00		33		8		24	
19	水																														
20	木																														
21	金																														
22	土																														
23	日																														
24	月																														
25	火																														
26	水																														
27	木																														
28	金																														
29	土																														
30	日																														
最大		3	4	2	2	2	2	9	10	6	5	7	7	32	29	17	13	24	23	0.00	0.00	0.00	0.00	0.00	0.00	40	36	18	13	27	23
最小		2	2	2	1	2	1	5	5	0	0	3	2	21	13	6	1	14	9	0.00	0.00	0.00	0.00	0.00	0.00	31	24	7	5	21	16
平均		3	2	2	2	2	2	7	7	3	2	5	5	27	24	12	7	20	15	0.00	0.00	0.00	0.00	0.00	0.00	35	31	12	9	24	20
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考	運転管理に基づき 2号炉 6月17日立下げ 1号炉 6月18日立下げ 休炉																														