

# 施設排ガス測定データ

2019年 8月	曜日	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	木	1	3	1	2	1	2	10	7	3	3	6	5	30	29	18	16	25	23	0.00	0.00	0.00	0.00	0.00	0.00	37	31	4	6	19	20
2	金	2	3	1	2	1	2	8	7	4	3	6	5	28	28	16	13	23	21	0.00	0.00	0.00	0.00	0.00	0.00	35	31	6	4	20	19
3	土	2	3	1	2	1	2	10	7	2	3	5	5	28	27	7	16	18	22	0.00	0.00	0.00	0.00	0.00	0.00	37	30	7	12	20	22
4	日	7	3	1	2	1	2	8	7	2	4	6	5	27	24	9	14	19	19	0.00	0.00	0.00	0.00	0.00	0.00	34	35	8	12	22	21
5	月	2	2	1	1	1	2	7	7	2	1	4	4	28	25	12	5	20	15	0.00	0.00	0.00	0.00	0.00	0.00	31	31	5	8	16	18
6	火	2	2	1	2	1	2	9	7	3	2	5	4	30	25	14	8	21	17	0.00	0.00	0.00	0.00	0.00	0.00	40	33	7	16	24	24
7	水	6	3	1	2	1	2	10	7	3	1	5	5	28	28	5	3	19	18	0.00	0.00	0.00	0.00	0.00	0.00	33	37	6	4	24	21
8	木	2	3	1	2	1	2	7	6	2	2	5	4	23	21	3	6	16	14	0.00	0.00	0.00	0.00	0.00	0.00	37	33	7	6	20	20
9	金	1	2	1	2	1	2	7	7	3	2	5	4	26	22	15	8	21	13	0.00	0.00	0.00	0.00	0.00	0.00	32	33	12	11	24	24
10	土	2	3	1	2	1	2	7	6	3	2	5	4	30	25	13	11	22	16	0.00	0.00	0.00	0.00	0.00	0.00	36	38	9	2	24	18
11	日	3	3	1	2	1	2	8	7	2	4	6	5	30	27	3	13	17	20	0.00	0.00	0.00	0.00	0.00	0.00	37	35	9	3	22	20
12	月	5	3	1	2	1	2	8	7	3	2	6	5	29	27	8	11	21	19	0.00	0.00	0.00	0.00	0.00	0.00	40	37	7	8	21	21
13	火	2	2	1	2	1	2	9	5	1	1	3	2	24	23	5	2	12	11	0.00	0.00	0.00	0.00	0.00	0.00	37	34	5	6	19	19
14	水	2	2	1	2	1	2	8	5	2	1	5	2	21	15	6	4	14	9	0.00	0.00	0.00	0.00	0.00	0.00	36	39	11	3	20	20
15	木	1	2	1	2	1	2	6	4	2	1	4	2	24	16	13	6	18	11	0.00	0.00	0.00	0.00	0.00	0.00	31	33	13	3	21	20
16	金	1	2	1	2	1	2	5	6	2	1	3	3	27	24	9	7	17	13	0.00	0.00	0.00	0.00	0.00	0.00	35	36	6	3	20	20
17	土	1	2	1	1	1	2	8	7	3	3	5	4	27	27	13	11	24	18	0.00	0.00	0.00	0.00	0.00	0.00	42	37	7	6	23	20
18	日	1	8	1	1	1	2	7	9	4	2	5	4	27	26	14	7	22	16	0.00	0.00	0.00	0.00	0.00	0.00	39	36	7	3	20	21
19	月	1	2	1	1	1	2	8	6	2	1	4	4	28	22	13	4	21	14	0.00	0.00	0.00	0.00	0.00	0.00	38	32	8	6	21	17
20	火	1	3	1	1	1	2	12	7	1	2	5	4	29	20	7	7	21	15	0.00	0.00	0.00	0.00	0.00	0.00	38	33	9	7	20	22
21	水	1	2	1	2	1	2	6	5	2	1	4	3	29	25	18	7	25	13	0.00	0.00	0.00	0.00	0.00	0.00	35	35	9	9	22	22
22	木	1	2	1	2	1	2	5	4	2	1	3	3	29	22	18	5	25	16	0.00	0.00	0.00	0.00	0.00	0.00	39	38	8	9	21	24
23	金	1	2	1	2	1	2	7	7	2	2	4	4	28	27	12	11	23	21	0.00	0.00	0.00	0.00	0.00	0.00	36	35	4	5	19	22
24	土	1	2	1	1	1	2	7	6	3	2	5	4	27	27	14	11	22	20	0.00	0.00	0.00	0.00	0.00	0.00	40	39	5	2	22	21
25	日	1	2	1	1	1	2	6	6	1	1	3	4	30	27	14	10	23	21	0.00	0.00	0.00	0.00	0.00	0.00	37	38	11	2	23	17
26	月	1	2	1	1	1	1	5	6	1	2	4	4	29	28	10	13	25	21	0.00	0.00	0.00	0.00	0.00	0.00	36	36	11	6	22	18
27	火	1	2	1	1	1	1	6	6	1	2	4	4	28	24	10	10	22	18	0.00	0.00	0.00	0.00	0.00	0.00	31	36	5	12	19	21
28	水	1	2	1	1	1	2	4	6	2	2	3	4	31	29	12	12	24	26	0.00	0.00	0.00	0.00	0.00	0.00	40	40	7	3	22	20
29	木	1	9	1	2	1	2	6	6	2	2	4	4	28	29	12	12	22	22	0.00	0.00	0.00	0.00	0.00	0.00	38	34	5	7	22	24
30	金	1	2	1	1	1	2	7	6	1	2	3	4	29	25	8	8	21	17	0.00	0.00	0.00	0.00	0.00	0.00	42	37	10	3	24	21
31	土	1	2	1	2	1	2	9	5	1	2	4	4	28	25	5	11	21	18	0.00	0.00	0.00	0.00	0.00	0.00	32	29	11	10	22	21
最大		7	9	1	2	1	2	12	9	4	4	6	5	31	29	18	16	25	26	0.00	0.00	0.00	0.00	0.00	0.00	42	40	13	16	24	24
最小		1	2	1	1	1	1	4	4	1	1	3	2	21	15	3	2	12	9	0.00	0.00	0.00	0.00	0.00	0.00	31	29	4	2	16	17
平均		2	3	1	2	1	2	7	6	2	2	4	4	28	25	11	9	21	17	0.00	0.00	0.00	0.00	0.00	0.00	36	35	8	6	21	21
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m <sup>3</sup> N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m <sup>3</sup> N						250 ppm					
※ 備考		設備保全に伴い 1号炉 8月26日立下げ 立上げ <span style="background-color: #cccccc; padding: 2px;">          </span> 休炉																													