

施設排ガス測定データ

2019年 9月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	日	1	2	1	2	1	2	7	6	3	1	5	4	30	26	19	6	25	16	0.00	0.00	0.00	0.00	0.00	0.00	42	31	9	8	19	20
2	月	1	3	1	2	1	2	7	4	2	2	4	3	30	22	14	8	22	15	0.00	0.00	0.00	0.00	0.00	0.00	37	37	7	11	22	22
3	火	1	3	1	2	1	2	7	6	1	1	3	3	28	27	9	4	17	15	0.00	0.00	0.00	0.00	0.00	0.00	35	28	7	7	20	17
4	水	1	3	1	2	1	2	6	6	3	2	5	5	25	25	12	9	20	16	0.00	0.00	0.00	0.00	0.00	0.00	32	28	13	14	23	20
5	木	1	2	1	2	1	2	5	6	2	2	3	4	23	25	10	10	17	16	0.00	0.00	0.00	0.00	0.00	0.00	31	27	5	11	21	20
6	金	1	3	1	2	1	2	6	5	2	2	3	3	23	21	9	8	16	14	0.00	0.00	0.00	0.00	0.00	0.00	34	30	11	13	22	20
7	土	1	3	1	2	1	2	7	6	2	1	5	4	29	25	11	9	22	16	0.00	0.00	0.00	0.00	0.00	0.00	35	36	8	4	20	18
8	日	1	7	1	2	1	3	7	7	3	1	5	3	28	18	12	3	23	11	0.00	0.00	0.00	0.00	0.00	0.00	34	35	8	7	22	22
9	月	1	2	1	2	1	2	7	5	2	2	4	4	28	21	10	7	19	13	0.00	0.00	0.00	0.00	0.00	0.00	35	36	7	4	23	18
10	火	2	2	1	2	1	2	7	5	3	2	5	4	28	22	14	5	21	14	0.00	0.00	0.00	0.00	0.00	0.00	35	34	10	6	22	21
11	水	1	3	1	2	1	2	6	6	1	1	4	3	31	22	11	2	25	12	0.00	0.00	0.00	0.00	0.00	0.00	41	36	5	5	21	21
12	木	1	2	1	2	1	2	7	6	2	2	4	4	30	26	18	14	26	20	0.00	0.00	0.00	0.00	0.00	0.00	37	31	5	5	19	18
13	金	10	2	1	1	1	2	8	7	1	2	4	4	29	28	5	11	24	24	0.00	0.00	0.00	0.00	0.00	0.00	44	36	9	4	21	20
14	土	1	3	1	1	1	2	4	7	2	1	3	4	29	27	10	6	20	16	0.00	0.00	0.00	0.00	0.00	0.00	36	41	3	3	19	17
15	日		2		2		2		7		3		4		24		11		17		0.00		0.00		0.00		32		6		21
16	月		2		2		2		5		1		4		19		3		13		0.00		0.00		0.00		28		6		22
17	火		2		1		2		6		2		3		20		5		10		0.00		0.00		0.00		29		17		24
18	水		2		2		2		7		2		3		24		6		13		0.00		0.00		0.00		30		8		22
19	木		2		1		2		6		3		4		30		19		25		0.00		0.00		0.00		33		9		22
20	金		2		1		1		7		2		4		28		12		19		0.00		0.00		0.00		33		13		24
21	土		2		1		1		6		2		3		24		10		16		0.00		0.00		0.00		30		10		22
22	日		2		1		2		10		0		3		28		6		16		0.00		0.00		0.00		36		4		18
23	月		3		2		2		5		1		3		18		9		14		0.00		0.00		0.00		36		4		18
24	火		3		1		2		7		1		3		19		8		14		0.00		0.00		0.00		35		6		21
25	水		2		1		2		5		0		3		28		7		17		0.00		0.00		0.00		41		3		17
26	木		3		1		2		7		1		3		24		12		18		0.00		0.00		0.00		38		9		21
27	金		2		1		2		5		1		3		25		10		18		0.00		0.00		0.00		40		5		19
28	土		2		1		2		7		2		4		27		10		20		0.00		0.00		0.00		34		7		20
29	日		2		1		2		6		1		3		21		9		16		0.00		0.00		0.00		37		4		19
30	月		2		1		2		4		1		3		24		12		17		0.00		0.00		0.00		37		7		22
最大		10	7	1	2	1	3	8	10	3	3	5	5	31	30	19	19	26	25	0.00	0.00	0.00	0.00	0.00	0.00	44	41	13	17	23	24
最小		1	2	1	1	1	1	4	4	1	0	3	3	23	18	5	2	16	10	0.00	0.00	0.00	0.00	0.00	0.00	31	27	3	3	19	17
平均		2	3	1	2	1	2	7	6	2	2	4	4	28	24	12	8	21	16	0.00	0.00	0.00	0.00	0.00	0.00	36	34	8	7	21	20
自主規制値		30 ppm				20 ppm				50 ppm				0.01 g/m ³ N				50 ppm													
法規制値		30 ppm				3,500 ppm相当				430 ppm				0.04 g/m ³ N				250 ppm													
※ 備考		運転管理に基づき		1号炉		9月14日立下げ																				休炉					