

施設排ガス測定データ

2020年 1月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	水	1		0		1		7		2		5		28		5		20		0.00		0.00		0.00		37		10		25	
2	木	1		0		1		7		2		5		27		10		23		0.00		0.00		0.00		38		11		26	
3	金	1		1		1		7		3		5		32		15		23		0.00		0.00		0.00		35		10		26	
4	土	1		0		1		5		1		3		26		9		18		0.00		0.00		0.00		38		14		27	
5	日	1		1		1		6		0		4		25		3		17		0.00		0.00		0.00		37		13		26	
6	月	1		0		1		5		0		3		26		5		17		0.00		0.00		0.00		35		11		25	
7	火	1		1		1		6		1		3		25		13		19		0.00		0.00		0.00		38		9		24	
8	水	1		1		1		6		1		3		25		7		19		0.00		0.00		0.00		36		15		27	
9	木	1		1		1		4		1		2		28		14		20		0.00		0.00		0.00		38		8		24	
10	金	1		1		1		5		1		2		30		8		22		0.00		0.00		0.00		37		9		25	
11	土	1		1		1		4		1		3		26		8		20		0.00		0.00		0.00		37		12		26	
12	日	1		1		1		5		2		4		32		17		24		0.00		0.00		0.00		36		10		24	
13	月	1		1		1		6		2		3		28		12		22		0.00		0.00		0.00		37		11		24	
14	火	1		1		1		4		1		3		30		14		22		0.00		0.00		0.00		38		10		25	
15	水	1		1		1		4		2		3		27		16		21		0.00		0.00		0.00		40		11		23	
16	木	1		1		1		6		2		3		29		7		23		0.00		0.00		0.00		38		13		25	
17	金	1	立上げ	0	立上げ	1	立上げ	6	立上げ	1	立上げ	3	立上げ	34	立上げ	11	立上げ	24	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	35	立上げ	10	立上げ	23	立上げ
18	土	1	2	1	1	1	1	4	7	1	2	3	4	27	26	15	8	23	19	0.00	0.00	0.00	0.00	0.00	0.00	37	32	16	4	27	18
19	日	1	2	0	1	1	1	4	6	1	2	2	3	29	28	16	11	22	17	0.00	0.00	0.00	0.00	0.00	0.00	39	27	10	17	25	22
20	月	1	3	1	1	1	1	5	7	2	2	3	5	27	26	17	12	23	20	0.00	0.00	0.00	0.00	0.00	0.00	37	29	11	4	24	20
21	火	1	2	0	1	1	1	5	6	1	0	2	3	27	22	12	5	19	14	0.00	0.00	0.00	0.00	0.00	0.00	33	24	11	4	25	16
22	水	2	1	1	1	1	1	13	7	0	2	3	4	26	24	5	9	16	17	0.00	0.00	0.00	0.00	0.00	0.00	40	33	7	6	21	21
23	木	1	1	0	1	1	1	4	6	2	1	3	3	30	25	22	5	25	14	0.00	0.00	0.00	0.00	0.00	0.00	35	27	12	12	24	21
24	金	1	2	1	1	1	1	4	6	1	1	2	4	37	27	17	8	27	20	0.00	0.00	0.00	0.00	0.00	0.00	37	30	17	8	27	19
25	土	1	3	1	1	1	1	4	6	1	0	3	3	34	24	17	7	25	15	0.00	0.00	0.00	0.00	0.00	0.00	35	35	8	4	22	22
26	日	1	1	0	1	1	1	8	8	2	0	4	4	28	24	12	9	20	18	0.00	0.00	0.00	0.00	0.00	0.00	35	29	10	3	22	21
27	月	1	1	1	1	1	1	7	6	3	0	4	4	31	27	12	4	22	20	0.00	0.00	0.00	0.00	0.00	0.00	35	32	8	7	22	24
28	火	1	2	1	1	1	1	5	6	1	1	4	4	27	28	8	11	22	23	0.00	0.00	0.00	0.00	0.00	0.00	37	33	9	4	24	18
29	水	1	2	0	1	1	1	6	7	2	3	4	5	31	29	14	15	25	23	0.00	0.00	0.00	0.00	0.00	0.00	36	33	8	8	23	21
30	木	1	2	1	1	1	2	5	5	1	3	3	4	30	28	15	18	26	25	0.00	0.00	0.00	0.00	0.00	0.00	37	32	10	14	23	21
31	金	3	2	0	1	1	1	5	5	2	2	4	3	29	29	9	13	22	23	0.00	0.00	0.00	0.00	0.00	0.00	36	30	8	9	23	22
最大		3	3	1	1	1	2	13	8	3	3	5	5	37	29	22	18	27	25	0.00	0.00	0.00	0.00	0.00	0.00	40	35	17	17	27	24
最小		1	1	0	1	1	1	4	5	0	0	2	3	25	22	3	4	16	14	0.00	0.00	0.00	0.00	0.00	0.00	33	24	7	3	21	16
平均		1	2	1	1	1	1	6	6	1	1	3	4	29	26	12	10	22	19	0.00	0.00	0.00	0.00	0.00	0.00	37	30	11	7	24	20
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考		運転管理に基づき 2号炉 1月17日立上げ																								休炉					