

施設排ガス測定データ

2020年 4月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)							
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均			
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号		
1	水	1		0		0		7		3		5		25		7		15		0.00		0.00		0.00		35		14		24		
2	木	1		0		0		6		1		4		25		3		17		0.00		0.00		0.00		37		9		23		
3	金	1		0		0		6		2		4		25		2		16		0.00		0.00		0.00		32		17		25		
4	土	1		0		0		8		4		6		25		11		19		0.00		0.00		0.00		40		14		24		
5	日	1		0		0		7		4		5		29		13		20		0.00		0.00		0.00		38		10		25		
6	月	1		0		1		7		1		4		24		1		19		0.00		0.00		0.00		40		10		25		
7	火	1		0		1		7		3		5		26		10		15		0.00		0.00		0.00		36		14		25		
8	水	1		0		1		7		3		5		24		10		14		0.00		0.00		0.00		37		16		26		
9	木	5		0		1		6		2		4		23		7		15		0.00		0.00		0.00		32		15		24		
10	金	1		0		0		7		1		5		23		1		13		0.00		0.00		0.00		35		12		24		
11	土	1		0		1		6		2		5		25		6		16		0.00		0.00		0.00		33		19		26		
12	日	5		0		1		8		2		4		23		1		12		0.00		0.00		0.00		40		10		25		
13	月	1		0		0		8		4		6		25		11		19		0.00		0.00		0.00		37		15		27		
14	火	1	立上げ	0	立上げ	0	立上げ	7	立上げ	3	立上げ	5	立上げ	24	立上げ	12	立上げ	18	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	37	立上げ	13	立上げ	25	立上げ	
15	水	1	2	0	1	0	1	6	6	3	3	5	5	29	19	10	9	17	14	0.00	0.00	0.00	0.00	0.00	0.00	36	28	13	6	25	19	
16	木	1	2	0	1	0	1	7	7	4	3	5	5	27	22	10	11	17	15	0.00	0.00	0.00	0.00	0.00	0.00	35	30	18	14	26	21	
17	金	2	1	0	1	1	1	10	8	3	4	6	6	21	26	3	8	12	17	0.00	0.00	0.00	0.00	0.00	0.00	40	29	13	11	25	20	
18	土	1	2	0	1	0	1	7	7	2	1	5	4	25	26	1	4	15	13	0.00	0.00	0.00	0.00	0.00	0.00	36	24	8	8	25	14	
19	日	2	1	0	1	1	1	8	9	4	1	6	6	28	30	5	6	19	17	0.00	0.00	0.00	0.00	0.00	0.00	37	25	14	11	24	19	
20	月	2	1	0	1	0	1	6	8	2	4	5	5	28	30	4	11	19	20	0.00	0.00	0.00	0.00	0.00	0.00	38	21	15	12	26	16	
21	火	1	1	0	1	0	1	7	7	4	3	6	5	27	23	11	7	20	17	0.00	0.00	0.00	0.00	0.00	0.00	38	28	10	13	24	18	
22	水	1	1	0	1	1	1	8	7	3	3	6	6	25	21	12	11	21	14	0.00	0.00	0.00	0.00	0.00	0.00	34	24	10	8	24	16	
23	木	1	2	0	1	1	1	8	7	1	2	5	5	27	20	3	6	15	13	0.00	0.00	0.00	0.00	0.00	0.00	40	22	6	5	21	16	
24	金	1	2	1	1	1	1	8	7	3	5	6	6	22	28	7	17	20	21	0.00	0.00	0.00	0.00	0.00	0.00	36	28	10	14	23	20	
25	土		2		1		1		8		4		6		26		11		18		0.00		0.00		0.00		27		6		20	
26	日		2		1		1		9		2		6		17		5		12		0.00		0.00		0.00		30		5		19	
27	月		2		1		1		8		4		6		20		9		13		0.00		0.00		0.00		27		12		21	
28	火		2		1		1		8		3		6		18		8		12		0.00		0.00		0.00		26		5		16	
29	水		2		1		2		7		4		6		17		7		13		0.00		0.00		0.00		28				21	
30	木		2		1		2		7		4		7		24		10		18		0.00		0.00		0.00		29		8		19	
最大		5	2	1	1	1	2	10	9	4	5	6	7	29	30	13	17	21	21	0.00	0.00	0.00	0.00	0.00	0.00	40	30	19	14	27	21	
最小		1	1	0	1	0	1	6	6	1	1	4	4	21	17	1	4	12	12	0.00	0.00	0.00	0.00	0.00	0.00	32	21	6	5	21	14	
平均		1	2	0	1	0	1	7	8	3	3	5	6	25	23	7	9	17	15	0.00	0.00	0.00	0.00	0.00	0.00	37	27	13	10	25	18	
自主規制値		30				ppm		20				ppm		50				ppm		0.01				g/m ³ N		50				ppm		
法規制値		30				ppm		3,500				ppm 相当		430				ppm		0.04				g/m ³ N		250				ppm		
※ 備考	運転管理に基づき		2号炉		4月14日立上げ		1号炉		4月24日立下げ																		休炉					