

施設排ガス測定データ

2020年 5月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	金		8		1		2		8		4		6		26		7		16		0.00		0.00		0.00		29		7		19
2	土		2		1		2		8		4		7		21		10		17		0.00		0.00		0.00		29		6		22
3	日		2		1		2		8		4		6		21		11		17		0.00		0.00		0.00		34		11		24
4	月		2		1		2		7		4		6		17		6		13		0.00		0.00		0.00		28		6		19
5	火		2		1		2		7		3		5		22		6		11		0.00		0.00		0.00		30		21		26
6	水		3		2		2		7		2		5		17		6		11		0.00		0.00		0.00		30		9		22
7	木		2		1		2		7		2		5		19		5		11		0.00		0.00		0.00		28		11		21
8	金		2		1		1		8		3		5		28		7		15		0.00		0.00		0.00		33		9		21
9	土		2		1		1		8		3		5		23		8		14		0.00		0.00		0.00		30		11		22
10	日		2		2		2		8		4		6		19		8		13		0.00		0.00		0.00		30		10		23
11	月		2		1		2		7		5		6		20		8		15		0.00		0.00		0.00		32		10		23
12	火	2	2	2	1	2	2	7	7	7	4	7	6	9	21	7	8	8	15	0.00	0.00	0.00	0.00	0.00	0.00	36	36	9	6	21	19
13	水	5	2	1	1	1	2	8	8	1	4	6	7	13	20	4	10	8	15	0.00	0.00	0.00	0.00	0.00	0.00	41	26	9	7	23	19
14	木	2	4	1	1	1	2	7	7	3	4	6	6	16	23	5	9	11	16	0.00	0.00	0.00	0.00	0.00	0.00	32	27	10	17	23	21
15	金	3	2	1	1	1	2	8	7	3	4	6	6	21	29	3	8	11	18	0.00	0.00	0.00	0.00	0.00	0.00	37	30	9	6	21	19
16	土	1	6	1	1	1	2	8	8	2	2	6	6	18	27	0	6	7	15	0.00	0.00	0.00	0.00	0.00	0.00	36	37	9	5	22	18
17	日	2	2	1	2	1	2	8	8	2	2	6	6	17	21	4	7	10	16	0.00	0.00	0.00	0.00	0.00	0.00	40	38	9	10	21	19
18	月	1	6	1	1	1	2	8	7	3	4	6	6	21	25	4	8	13	17	0.00	0.00	0.00	0.00	0.00	0.00	39	26	9	13	22	20
19	火	1	2	0	1	1	2	9	8	3	2	6	6	27	21	12	7	17	15	0.00	0.00	0.00	0.00	0.00	0.00	35	31	11	4	21	19
20	水	1	2	0	1	0	1	7	7	5	3	6	6	18	31	11	10	15	18	0.00	0.00	0.00	0.00	0.00	0.00	40	27	12	18	20	22
21	木		2		1		1		7		3		5		30		5		19		0.00		0.00		0.00		29		8		23
22	金	立上げ	2	立上げ	1	立上げ	1	立上げ	8	立上げ	4	立上げ	6	立上げ	24	立上げ	10	立上げ	14	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	32	立上げ	8	立上げ	20
23	土	1	2	1	1	1	2	8	8	4	2	6	6	17	23	8	7	12	16	0.00	0.00	0.00	0.00	0.00	0.00	38	25	10	9	21	19
24	日	1	2	0	1	1	1	8	8	1	4	5	6	24	30	4	10	14	19	0.00	0.00	0.00	0.00	0.00	0.00	37	31	9	19	22	23
25	月	2	2	1	1	1	2	8	7	2	4	5	6	26	25	4	11	15	18	0.00	0.00	0.00	0.00	0.00	0.00	32	28	14	14	22	22
26	火	6	2	0	1	1	1	7	8	1	4	5	6	27	25	9	9	17	14	0.00	0.00	0.00	0.00	0.00	0.00	34	28	7	15	21	21
27	水	1	1	0	1	1	1	7	7	2	1	5	4	21	16	6	3	15	9	0.00	0.00	0.00	0.00	0.00	0.00	36	26	9	8	21	20
28	木	1	2	0	1	1	1	8	8	1	0	6	5	19	19	6	3	11	12	0.00	0.00	0.00	0.00	0.00	0.00	36	27	9	4	21	15
29	金	1	2	0	1	1	1	9	9	3	4	6	7	24	23	7	9	14	15	0.00	0.00	0.00	0.00	0.00	0.00	33	28	15	8	23	19
30	土	2	2	0	1	1	1	11	8	5	6	7	7	19	31	8	13	12	21	0.00	0.00	0.00	0.00	0.00	0.00	34	27	14	12	22	21
31	日	1	1	0	1	1	1	9	9	5	5	7	7	21	31	7	16	12	22	0.00	0.00	0.00	0.00	0.00	0.00	36	19	5	4	18	9
最大		6	8	2	2	2	2	11	9	7	6	7	7	27	31	12	16	17	22	0.00	0.00	0.00	0.00	0.00	0.00	41	38	15	21	23	26
最小		1	1	0	1	0	1	7	7	1	0	5	4	9	16	0	3	7	9	0.00	0.00	0.00	0.00	0.00	0.00	32	19	5	4	18	9
平均		2	2	1	1	1	2	8	8	3	3	6	6	20	23	6	8	12	15	0.00	0.00	0.00	0.00	0.00	0.00	36	29	10	10	21	20
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考	運転管理に基づき 1号炉 5月12日立上げ 設備保全に伴い 1号炉 5月20日立下げ 5月22日立上げ																														
		休炉																													