

施設排ガス測定データ

2020年 6月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	月	1	2	0	1	1	1	9	8	5	4	7	6	25	25	8	10	14	17	0.00	0.00	0.00	0.00	0.00	0.00	34	30	7	3	21	11
2	火	1	6	0	1	1	2	8	7	4	3	7	6	21	27	5	6	11	16	0.00	0.00	0.00	0.00	0.00	0.00	33	26	12	15	23	21
3	水	1	3	0	1	1	2	8	8	5	3	7	6	25	22	7	5	11	15	0.00	0.00	0.00	0.00	0.00	0.00	37	29	10	11	21	21
4	木	1	2	0	1	1	2	8	8	5	5	7	7	17	29	9	10	12	18	0.00	0.00	0.00	0.00	0.00	0.00	34	29	12	18	23	22
5	金	2	2	0	1	1	2	9	7	1	3	5	6	28	27	0	14	14	22	0.00	0.00	0.00	0.00	0.00	0.00	33	30	7	6	19	17
6	土	3	2	1	1	1	2	11	9	4	5	7	7	21	23	5	10	9	15	0.00	0.00	0.00	0.00	0.00	0.00	27	32	10	10	20	23
7	日	3	2	1	1	1	2	9	8	4	4	7	6	21	27	9	12	14	18	0.00	0.00	0.00	0.00	0.00	0.00	28	30	9	16	20	23
8	月	1	2	1	1	1	2	7	7	4	3	6	5	16	17	5	8	10	12	0.00	0.00	0.00	0.00	0.00	0.00	24	30	12	12	19	20
9	火	1	2	1	1	1	2	8	8	4	4	7	6	24	18	5	8	11	12	0.00	0.00	0.00	0.00	0.00	0.00	24	32	9	9	15	16
10	水	1	2	1	2	1	2	12	8	5	5	7	6	14	18	4	11	9	13	0.00	0.00	0.00	0.00	0.00	0.00	28	23	13	11	19	17
11	木	1	2	1	2	1	2	9	8	4	4	7	6	17	18	4	8	8	13	0.00	0.00	0.00	0.00	0.00	0.00	28	29	9	10	17	19
12	金	1	2	1	2	1	2	8	7	4	2	7	6	26	16	4	6	7	11	0.00	0.00	0.00	0.00	0.00	0.00	25	31	13	8	18	19
13	土	2	2	1	2	1	2	8	8	4	2	7	5	22	21	5	6	8	12	0.00	0.00	0.00	0.00	0.00	0.00	24	27	12	11	18	19
14	日	1	2	1	2	1	2	8	6	1	3	6	5	16	18	0	9	10	13	0.00	0.00	0.00	0.00	0.00	0.00	28	25	12	15	19	19
15	月	7	7	1	7	1	7	12	5	1	5	6	5	26	5	0	5	9	5	0.00	0.00	0.00	0.00	0.00	0.00	25	17	8	17	16	17
16	火	1	6	1	2	1	3	9	7	3	4	6	6	10	24	3	6	6	13	0.00	0.00	0.00	0.00	0.00	0.00	22	25	14	5	18	16
17	水	2	3	1	1	1	2	10	8	3	3	6	6	16	24	1	10	8	16	0.00	0.00	0.00	0.00	0.00	0.00	25	32	8	13	16	20
18	木	1	2	0	1	1	2	10	8	4	4	7	6	11	16	3	8	7	12	0.00	0.00	0.00	0.00	0.00	0.00	25	27	10	8	16	17
19	金	1	2	0	1	1	2	9	8	1	4	5	6	24	13	0	6	8	9	0.00	0.00	0.00	0.00	0.00	0.00	28	27	6	10	14	17
20	土	1	2	0	1	1	2	8	8	5	5	6	6	19	13	3	6	9	10	0.00	0.00	0.00	0.00	0.00	0.00	33	33	7	9	15	21
21	日	1	3	0	1	1	2	8	8	3	5	6	7	20	15	6	7	11	11	0.00	0.00	0.00	0.00	0.00	0.00	27	32	14	9	19	21
22	月	1	2	1	2	1	2	8	8	4	4	6	6	15	15	7	7	11	11	0.00	0.00	0.00	0.00	0.00	0.00	28	32	12	13	19	23
23	火		2		1		2		6		2		4		14		4		8		0.00		0.00		0.00		26		8		18
24	水																														
25	木																														
26	金																														
27	土																														
28	日																														
29	月																														
30	火																														
最大		7	7	1	7	1	7	12	9	5	5	7	7	28	29	9	14	14	22	0.00	0.00	0.00	0.00	0.00	0.00	37	33	14	18	23	23
最小		1	2	0	1	1	1	7	5	1	2	5	4	10	5	0	4	6	5	0.00	0.00	0.00	0.00	0.00	0.00	22	17	6	3	14	11
平均		2	3	1	2	1	2	9	8	4	4	6	6	20	19	4	8	10	13	0.00	0.00	0.00	0.00	0.00	0.00	28	28	10	11	18	19
自主規制値		30				ppm		20				ppm		50				ppm		0.01				g/m ³ N		50				ppm	
法規制値		30				ppm		3,500				ppm 相当		430				ppm		0.04				g/m ³ N		250				ppm	
※ 備考	運転管理に基づき		1号炉		6月22日立下げ		2号炉		6月23日立下げ		1号炉		6月20日立下げ		立上げ												休炉				
	設備保全に伴い		2号炉		6月14日立下げ		6月15日立上げ																								