

施設排ガス測定データ

2020年 8月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	土	1	2	1	2	1	2	8	8	3	4	6	6	27	24	13	10	19	15	0.00	0.00	0.00	0.00	0.00	0.00	26	30	6	15	14	23
2	日	2	3	1	2	1	2	8	7	1	4	6	6	26	20	5	11	20	15	0.00	0.00	0.00	0.00	0.00	0.00	26	27	4	10	15	19
3	月	1	2	1	2	1	2	7	7	2	3	5	5	23	19	5	5	16	11	0.00	0.00	0.00	0.00	0.00	0.00	27	26	6	10	13	18
4	火	2	5	1	1	1	2	7	7	1	2	6	5	22	17	6	4	14	11	0.00	0.00	0.00	0.00	0.00	0.00	28	35	4	4	11	16
5	水	2	3	1	2	1	2	8	7	5	5	7	7	22	17	12	9	18	13	0.00	0.00	0.00	0.00	0.00	0.00	27	33	9	4	17	15
6	木	1	2	1	1	1	2	10	7	2	3	6	6	26	20	9	9	20	15	0.00	0.00	0.00	0.00	0.00	0.00	28	32	9	5	15	15
7	金	1	3	1	2	1	2	7	7	3	3	5	5	29	26	13	8	20	15	0.00	0.00	0.00	0.00	0.00	0.00	20	32	6	14	12	19
8	土	2	3	1	2	1	2	8	7	3	3	6	6	25	19	10	7	16	13	0.00	0.00	0.00	0.00	0.00	0.00	19	25	7	12	13	19
9	日	2	13	1	2	1	3	10	7	2	2	7	6	24	19	4	4	14	12	0.00	0.00	0.00	0.00	0.00	0.00	29	34	7	7	15	17
10	月	2	3	1	2	1	2	8	7	4	4	6	6	16	19	7	6	12	14	0.00	0.00	0.00	0.00	0.00	0.00	25	28	6	10	14	18
11	火	2	2	1	2	1	2	8	6	1	1	6	3	25	12	4	0	13	6	0.00	0.00	0.00	0.00	0.00	0.00	20	23	7	6	13	12
12	水	2	2	1	2	1	2	8	7	3	2	6	4	28	19	13	3	20	11	0.00	0.00	0.00	0.00	0.00	0.00	26	25	8	6	16	19
13	木	2	3	1	2	1	2	7	7	3	4	6	6	29	20	9	9	20	14	0.00	0.00	0.00	0.00	0.00	0.00	28	31	6	14	16	20
14	金	2	11	1	2	1	3	7	7	3	2	6	6	21	18	14	5	18	13	0.00	0.00	0.00	0.00	0.00	0.00	23	25	11	15	16	20
15	土	2	3	1	2	1	2	9	8	2	4	5	6	21	19	8	10	18	14	0.00	0.00	0.00	0.00	0.00	0.00	21	25	12	14	16	17
16	日	1	3	1	2	1	2	8	7	2	4	5	5	20	22	10	7	17	14	0.00	0.00	0.00	0.00	0.00	0.00	24	30	10	12	16	19
17	月	2	4	1	2	1	2	8	7	2	2	5	5	20	16	8	7	17	11	0.00	0.00	0.00	0.00	0.00	0.00	24	37	6	6	13	19
18	火	2	3	1	2	1	2	5	7	2	2	4	4	23	20	13	8	18	12	0.00	0.00	0.00	0.00	0.00	0.00	25	29	5	11	14	19
19	水	2	2	1	2	1	2	5	6	0	3	4	5	22	24	5	11	18	17	0.00	0.00	0.00	0.00	0.00	0.00	21	34	5	9	15	20
20	木	2	3	1	2	1	2	9	8	0	4	3	6	21	23	2	14	16	18	0.00	0.00	0.00	0.00	0.00	0.00	26	31	4	5	15	18
21	金	2	7	1	2	2	2	8	7	2	5	5	6	21	25	12	12	18	18	0.00	0.00	0.00	0.00	0.00	0.00	27	30	11	5	18	21
22	土	2	3	1	2	2	2	11	7	2	2	6	6	26	29	12	6	18	17	0.00	0.00	0.00	0.00	0.00	0.00	31	29	11	7	19	19
23	日	2	3	1	2	2	2	8	8	2	5	6	6	20	26	12	11	17	17	0.00	0.00	0.00	0.00	0.00	0.00	27	31	8	5	18	21
24	月	2	2	1	1	1	2	8	8	2	3	5	6	19	24	10	12	15	18	0.00	0.00	0.00	0.00	0.00	0.00	28	33	6	3	16	15
25	火	2	2	1	2	1	2	7	7	2	3	5	5	18	22	4	11	13	16	0.00	0.00	0.00	0.00	0.00	0.00	28	35	7	11	17	21
26	水	2	2	1	2	2	2	8	7	2	4	6	6	17	24	6	9	14	16	0.00	0.00	0.00	0.00	0.00	0.00	31	31	6	13	15	23
27	木	2	2	1	2	1	2	8	8	2	5	6	6	19	20	9	10	13	14	0.00	0.00	0.00	0.00	0.00	0.00	32	33	8	6	18	23
28	金	2	2	1	2	1	2	8	7	3	2	6	6	19	25	11	6	15	16	0.00	0.00	0.00	0.00	0.00	0.00	31	36	8	8	18	21
29	土	2	8	1	2	1	2	7	8	2	4	6	6	19	19	9	8	13	13	0.00	0.00	0.00	0.00	0.00	0.00	30	33	13	6	20	21
30	日	1	3	1	2	1	2	7	7	2	4	5	6	21	23	8	11	16	16	0.00	0.00	0.00	0.00	0.00	0.00	28	30	6	11	19	22
31	月	1	2	1	2	1	2	6	6	3	3	5	4	27	20	12	10	19	14	0.00	0.00	0.00	0.00	0.00	0.00	29	34	9	7	19	20
最大		2	13	1	2	2	3	11	8	5	5	7	7	29	29	14	14	20	18	0.00	0.00	0.00	0.00	0.00	0.00	32	37	13	15	20	23
最小		1	2	1	1	1	2	5	6	0	1	3	3	16	12	2	0	12	6	0.00	0.00	0.00	0.00	0.00	0.00	19	23	4	3	11	12
平均		2	4	1	2	1	2	8	7	2	3	6	6	22	21	9	8	17	14	0.00	0.00	0.00	0.00	0.00	0.00	26	31	7	9	16	19
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m ³ N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m ³ N						250 ppm					
※ 備考		■■■■ 休炉																													