

施設排ガス測定データ

2020年 11月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m ³ N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	日	1	1	1	0	1	0	7	7	4	2	5	5	14	19	9	8	11	14	0.00	0.00	0.00	0.00	0.00	0.00	29	33	13	5	19	16
2	月		2		0		0		8		3		6		16		7		12		0.00		0.00		0.00		34		12		21
3	火		1		0		0		7		2		4		10		3		7		0.00		0.00		0.00		36		6		18
4	水		0		0		0		7		4		6		14		5		9		0.00		0.00		0.00		29		7		18
5	木		0		0		0		8		2		6		14		3		11		0.00		0.00		0.00		27		7		19
6	金		0		0		0		8		2		6		13		5		10		0.00		0.00		0.00		33		5		19
7	土		5		0		0		12		4		6		14		7		9		0.00		0.00		0.00		30		11		20
8	日		4		0		1		8		5		7		16		7		11		0.00		0.00		0.00		31		8		20
9	月		1		0		0		7		2		5		14		2		8		0.00		0.00		0.00		38		6		17
10	火	立上げ	0	立上げ	0	立上げ	0	立上げ	7	立上げ	3	立上げ	6	立上げ	13	立上げ	8	立上げ	10	立上げ	0.00	立上げ	0.00	立上げ	0.00	立上げ	35	立上げ	8	立上げ	19
11	水	2	2	1	0	1	1	6	7	1	3	3	5	12	15	2	8	8	10	0.00	0.00	0.00	0.00	0.00	0.00	31	30	7	8	15	19
12	木	1	9	1	2	1	2	8	7	1	3	4	5	16	15	3	7	10	11	0.00	0.00	0.00	0.00	0.00	0.00	34	31	5	5	17	16
13	金	1	2	1	1	1	2	7	6	2	2	5	4	22	15	8	7	12	11	0.00	0.00	0.00	0.00	0.00	0.00	29	32	10	5	20	17
14	土	1	2	1	1	1	2	7	6	2	0	4	3	16	20	7	5	10	10	0.00	0.00	0.00	0.00	0.00	0.00	37	30	9	5	20	16
15	日	2	2	1	2	1	2	7	7	0	1	4	4	15	21	3	7	9	13	0.00	0.00	0.00	0.00	0.00	0.00	37	30	4	9	19	20
16	月	1	2	1	2	1	2	6	5	1	1	4	3	15	18	5	7	10	11	0.00	0.00	0.00	0.00	0.00	0.00	30	32	11	6	19	17
17	火	1	2	1	2	1	2	7	6	1	1	4	3	21	12	4	4	14	8	0.00	0.00	0.00	0.00	0.00	0.00	30	30	8	7	20	18
18	水	1	5	1	2	1	2	7	6	0	2	3	4	18	16	3	4	11	10	0.00	0.00	0.00	0.00	0.00	0.00	30	28	9	8	17	18
19	木	1	2	1	2	1	2	7	7	2	1	5	4	22	19	8	5	14	12	0.00	0.00	0.00	0.00	0.00	0.00	28	28	9	7	18	19
20	金	1	3	1	2	1	2	7	6	2	2	4	4	22	18	8	7	15	12	0.00	0.00	0.00	0.00	0.00	0.00	26	31	9	6	17	17
21	土	1	2	1	2	1	2	7	6	1	2	4	4	22	20	7	8	14	14	0.00	0.00	0.00	0.00	0.00	0.00	31	29	7	3	17	13
22	日	1	2	1	2	1	2	7	6	1	2	5	4	20	24	5	9	13	14	0.00	0.00	0.00	0.00	0.00	0.00	26	31	7	5	14	16
23	月	1	2	1	2	1	2	8	7	1	2	5	4	26	22	9	11	17	15	0.00	0.00	0.00	0.00	0.00	0.00	26	30	8	11	18	20
24	火	1	2	0	1	1	2	8	7	3	1	5	4	20	21	10	9	14	14	0.00	0.00	0.00	0.00	0.00	0.00	30	27	9	3	17	15
25	水	1	2	0	1	1	2	8	9	2	1	5	4	28	22	8	7	17	12	0.00	0.00	0.00	0.00	0.00	0.00	29	28	8	4	19	18
26	木	1	2	0	1	1	2	8	6	4	1	6	3	29	16	15	8	21	12	0.00	0.00	0.00	0.00	0.00	0.00	28	31	11	7	18	18
27	金	1	2	0	2	1	2	8	5	2	1	6	3	26	14	7	6	19	10	0.00	0.00	0.00	0.00	0.00	0.00	30	33	6	2	18	17
28	土	1	2	1	1	1	2	7	6	0	2	4	4	23	22	3	9	16	13	0.00	0.00	0.00	0.00	0.00	0.00	29	29	7	5	17	16
29	日	1	3	0	1	1	2	7	6	3	1	5	3	31	24	15	7	22	15	0.00	0.00	0.00	0.00	0.00	0.00	31	30	12	12	20	18
30	月	1	2	0	1	1	2	8	7	3	3	6	5	28	25	12	10	20	16	0.00	0.00	0.00	0.00	0.00	0.00	30	25	7	8	15	17
最大		2	9	1	2	1	2	8	12	4	5	6	7	31	25	15	11	22	16	0.00	0.00	0.00	0.00	0.00	0.00	37	38	13	12	20	21
最小		1	0	0	0	1	0	6	5	0	0	3	3	12	10	2	2	8	7	0.00	0.00	0.00	0.00	0.00	0.00	26	25	4	2	14	13
平均		1	2	1	1	1	1	7	7	2	2	5	4	21	17	7	7	14	11	0.00	0.00	0.00	0.00	0.00	0.00	30	31	8	7	18	18
自主規制値		30				ppm		20				ppm		50				ppm		0.01				g/m ³ N		50				ppm	
法規制値		30				ppm		3,500				ppm 相当		430				ppm		0.04				g/m ³ N		250				ppm	
※ 備考		設備保全に伴い 1号炉 11月1日立下げ 11月10日立上げ																										休炉			