

施設排ガス測定データ

| 2021年 6月 | | 一酸化炭素 (ppm) | | | | | | 硫黄酸化物 (ppm) | | | | | | 塩化水素 (ppm) | | | | | | ばいじん (g/m ³ N) | | | | | | 窒素酸化物 (ppm) | | | | | |
|-------------|---|-----------------------|----|----|----|----|----|--------------|----|----|----|----|----|------------|----|----|----|----|----|---------------------------|------|------|------|------|------|-------------|----|----|----|----|----|
| | | 最大 | | 最小 | | 平均 | | 最大 | | 最小 | | 平均 | | 最大 | | 最小 | | 平均 | | 最大 | | 最小 | | 平均 | | 最大 | | 最小 | | 平均 | |
| | | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 | 1号 | 2号 |
| 1 | 火 | 2 | 3 | 1 | 1 | 1 | 2 | 7 | 7 | 2 | 0 | 4 | 3 | 31 | 27 | 5 | 3 | 20 | 16 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 28 | 28 | 9 | 0 | 17 | 12 |
| 2 | 水 | 2 | 2 | 1 | 1 | 1 | 2 | 6 | 9 | 2 | 2 | 4 | 4 | 30 | 22 | 9 | 7 | 18 | 13 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 30 | 33 | 14 | 5 | 20 | 17 |
| 3 | 木 | 2 | 2 | 1 | 2 | 1 | 2 | 7 | 7 | 3 | 2 | 5 | 5 | 30 | 29 | 7 | 9 | 21 | 21 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 30 | 33 | 16 | 9 | 21 | 17 |
| 4 | 金 | 2 | 2 | 1 | 2 | 1 | 2 | 7 | 6 | 2 | 2 | 5 | 4 | 30 | 32 | 3 | 19 | 20 | 28 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 34 | 32 | 16 | 11 | 22 | 20 |
| 5 | 土 | 2 | 7 | 1 | 2 | 2 | 2 | 7 | 6 | 2 | 1 | 4 | 4 | 32 | 30 | 6 | 11 | 22 | 26 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 29 | 30 | 12 | 7 | 20 | 17 |
| 6 | 日 | 2 | 2 | 1 | 2 | 1 | 2 | 7 | 7 | 2 | 2 | 4 | 4 | 32 | 29 | 6 | 17 | 23 | 25 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 29 | 33 | 17 | 11 | 23 | 20 |
| 7 | 月 | 2 | 2 | 1 | 1 | 2 | 2 | 8 | 7 | 2 | 1 | 5 | 4 | 32 | 32 | 5 | 13 | 21 | 23 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 30 | 35 | 11 | 5 | 19 | 16 |
| 8 | 火 | 2 | 2 | 1 | 1 | 2 | 2 | 6 | 6 | 1 | 2 | 4 | 4 | 29 | 31 | 7 | 17 | 20 | 25 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 32 | 31 | 16 | 9 | 21 | 19 |
| 9 | 水 | 2 | 2 | 1 | 1 | 1 | 2 | 5 | 5 | 1 | 1 | 3 | 3 | 32 | 32 | 7 | 18 | 22 | 26 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 32 | 29 | 14 | 12 | 22 | 20 |
| 10 | 木 | 2 | 4 | 1 | 1 | 1 | 2 | 7 | 6 | 3 | 1 | 5 | 4 | 31 | 29 | 15 | 10 | 25 | 23 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 27 | 32 | 12 | 9 | 20 | 19 |
| 11 | 金 | 3 | 2 | 1 | 1 | 1 | 2 | 7 | 7 | 1 | 3 | 4 | 5 | 31 | 33 | 2 | 14 | 19 | 26 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 36 | 29 | 16 | 11 | 23 | 19 |
| 12 | 土 | 2 | 2 | 1 | 1 | 1 | 2 | 6 | 6 | 2 | 2 | 4 | 4 | 30 | 37 | 5 | 6 | 19 | 24 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 39 | 39 | 13 | 7 | 24 | 19 |
| 13 | 日 | 1 | 2 | 1 | 1 | 1 | 1 | 8 | 7 | 1 | 1 | 3 | 5 | 29 | 30 | 3 | 15 | 11 | 22 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 33 | 29 | 16 | 7 | 22 | 14 |
| 14 | 月 | 1 | | 1 | | 1 | | 1 | | 1 | | 1 | | 21 | | 1 | | 5 | | 0.00 | | 0.00 | | 0.00 | | 34 | | 19 | | 25 | |
| 15 | 火 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 16 | 水 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 17 | 木 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 18 | 金 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 19 | 土 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 20 | 日 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 21 | 月 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 22 | 火 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 23 | 水 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 24 | 木 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 25 | 金 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 26 | 土 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 27 | 日 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 28 | 月 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 29 | 火 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 30 | 水 | | | | | | | | | | | | | | | | | | | | | | | | | | | | | | |
| 最大 | | 3 | 7 | 1 | 2 | 2 | 2 | 8 | 9 | 3 | 3 | 5 | 5 | 32 | 37 | 15 | 19 | 25 | 28 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 39 | 39 | 19 | 12 | 25 | 20 |
| 最小 | | 1 | 2 | 1 | 1 | 1 | 1 | 1 | 5 | 1 | 0 | 1 | 3 | 21 | 22 | 1 | 3 | 5 | 13 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 27 | 28 | 9 | 0 | 17 | 12 |
| 平均 | | 2 | 3 | 1 | 1 | 1 | 2 | 6 | 7 | 2 | 2 | 4 | 4 | 30 | 30 | 6 | 12 | 19 | 23 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 0.00 | 32 | 32 | 14 | 8 | 21 | 18 |
| 自主規制値 | | 30 ppm | | | | | | 20 ppm | | | | | | 50 ppm | | | | | | 0.01 g/m ³ N | | | | | | 50 ppm | | | | | |
| 法規制値 | | 30 ppm | | | | | | 3,500 ppm相当 | | | | | | 430 ppm | | | | | | 0.04 g/m ³ N | | | | | | 250 ppm | | | | | |
| ※ 備考 | | 運転管理に基づき 2号炉 6月13日立下げ | | | | | | 1号炉 6月14日立下げ | | | | | | | | | | | | 休炉 | | | | | | | | | | | |