

# 施設排ガス測定データ

2021年 7月	一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)						
	最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		
	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	
1	木																														
2	金																														
3	土																														
4	日																														
5	月																														
6	火																														
7	水																														
8	木																														
9	金																														
10	土																														
11	日																														
12	月		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ		立上げ
13	火		2		1		1		4		1		3		35		16		25		0.00		0.00		0.00		31		6		15
14	水	2	5	1	1	2	1	0	4	0	1	0	3	7	29	4	16	6	24	0.00	0.00	0.00	0.00	0.00	0.00	36	31	12	5	25	15
15	木	1	2	1	1	1	1	6	5	0	1	1	2	23	33	0	9	9	20	0.00	0.00	0.00	0.00	0.00	0.00	33	30	9	8	19	18
16	金	1	3	1	1	1	1	5	3	0	1	1	2	24	28	1	9	11	20	0.00	0.00	0.00	0.00	0.00	0.00	41	37	10	8	21	18
17	土	2	2	1	1	1	1	5	6	0	3	1	4	25	32	5	25	17	28	0.00	0.00	0.00	0.00	0.00	0.00	37	34	11	10	20	20
18	日	2	2	1	1	1	1	6	5	1	2	4	3	30	31	7	16	20	26	0.00	0.00	0.00	0.00	0.00	0.00	35	32	11	12	21	21
19	月	2	2	1	1	1	1	6	5	0	2	3	4	30	33	3	20	19	29	0.00	0.00	0.00	0.00	0.00	0.00	36	33	12	5	21	18
20	火	1	1	1	1	1	1	6	5	0	1	4	4	31	34	4	11	24	29	0.00	0.00	0.00	0.00	0.00	0.00	31	33	10	6	19	17
21	水	1	1	1	1	1	1	6	6	1	2	4	4	32	32	7	20	26	27	0.00	0.00	0.00	0.00	0.00	0.00	32	28	10	7	20	16
22	木	1	2	1	1	1	1	5	6	1	2	3	4	30	31	12	17	22	26	0.00	0.00	0.00	0.00	0.00	0.00	33	28	6	6	19	19
23	金	1	1	0	1	1	1	5	7	1	2	3	4	28	31	12	15	20	23	0.00	0.00	0.00	0.00	0.00	0.00	29	33	10	6	19	16
24	土	1	1	1	1	1	1	5	4	1	1	2	3	28	29	8	14	17	21	0.00	0.00	0.00	0.00	0.00	0.00	29	34	12	9	19	17
25	日	1	2	1	1	1	1	5	11	1	2	2	3	29	28	5	15	16	20	0.00	0.00	0.00	0.00	0.00	0.00	33	34	11	7	21	19
26	月	1	2	1	1	1	1	7	5	2	2	4	3	31	30	11	13	23	20	0.00	0.00	0.00	0.00	0.00	0.00	29	32	13	9	21	19
27	火	1	1	1	1	1	1	8	4	0	1	2	3	27	24	4	9	16	16	0.00	0.00	0.00	0.00	0.00	0.00	35	34	8	8	20	19
28	水	1	1	1	1	1	1	6	6	1	2	3	4	30	29	7	12	23	21	0.00	0.00	0.00	0.00	0.00	0.00	35	31	11	8	21	19
29	木	1	2	0	1	1	1	10	7	1	1	5	5	32	32	8	15	22	26	0.00	0.00	0.00	0.00	0.00	0.00	34	32	10	6	20	17
30	金	1	2	1	2	1	2	6	5	1	2	3	4	30	29	4	15	21	24	0.00	0.00	0.00	0.00	0.00	0.00	30	30	11	13	21	20
31	土	4	2	0	1	1	2	6	8	0	3	4	5	32	29	1	17	22	24	0.00	0.00	0.00	0.00	0.00	0.00	34	31	13	12	22	21
最大		4	5	1	2	2	2	10	11	2	3	5	5	32	35	12	25	26	29	0.00	0.00	0.00	0.00	0.00	0.00	41	37	13	13	25	21
最小		1	1	0	1	1	1	0	3	0	1	0	2	7	24	0	9	6	16	0.00	0.00	0.00	0.00	0.00	0.00	29	28	6	5	19	15
平均		1	2	1	1	1	1	6	6	1	2	3	4	28	30	6	15	19	24	0.00	0.00	0.00	0.00	0.00	0.00	33	32	11	8	21	18
自主規制値		30 ppm						20 ppm						50 ppm						0.01 g/m <sup>3</sup> N						50 ppm					
法規制値		30 ppm						3,500 ppm相当						430 ppm						0.04 g/m <sup>3</sup> N						250 ppm					
※ 備考	運転管理に基づき 2号炉 7月12日立上げ 1号炉 7月14日立上げ <span style="background-color: #cccccc; padding: 2px;">休炉</span>																														