

# 施設排ガス測定データ

2021年 9月		一酸化炭素 (ppm)						硫黄酸化物 (ppm)						塩化水素 (ppm)						ばいじん (g/m <sup>3</sup> N)						窒素酸化物 (ppm)					
		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均		最大		最小		平均	
		1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号	1号	2号
1	水	1	2	0	1	1	2	6	7	1	2	3	4	25	30	8	13	14	22	0.00	0.00	0.00	0.00	0.00	0.00	31	32	9	8	19	18
2	木	1	2	0	1	1	2	5	7	1	1	3	4	20	32	3	9	13	23	0.00	0.00	0.00	0.00	0.00	0.00	40	31	11	6	20	17
3	金	1	2	0	1	1	2	7	7	2	2	5	5	31	29	3	16	19	24	0.00	0.00	0.00	0.00	0.00	0.00	31	29	13	10	20	19
4	土	1	2	0	1	1	2	6	5	1	2	3	3	30	32	8	16	20	25	0.00	0.00	0.00	0.00	0.00	0.00	31	30	9	9	20	19
5	日	1	2	1	1	1	2	5	5	1	1	3	3	29	31	4	13	19	25	0.00	0.00	0.00	0.00	0.00	0.00	31	32	14	5	21	18
6	月	1	2	1	1	1	2	6	5	2	1	4	4	30	31	11	15	21	25	0.00	0.00	0.00	0.00	0.00	0.00	32	27	10	10	18	18
7	火	1	2	0	1	1	2	6	6	1	2	3	3	29	30	2	17	18	25	0.00	0.00	0.00	0.00	0.00	0.00	30	29	10	9	19	19
8	水	1	2	0	1	1	1	5	5	1	1	2	3	28	30	10	17	18	23	0.00	0.00	0.00	0.00	0.00	0.00	31	34	12	5	20	18
9	木	1	2	1	1	1	2	6	6	1	2	4	4	28	30	4	7	16	19	0.00	0.00	0.00	0.00	0.00	0.00	36	28	10	6	20	16
10	金	1	2	0	1	1	2	5	4	0	1	3	3	28	28	0	11	18	19	0.00	0.00	0.00	0.00	0.00	0.00	30	28	6	6	19	16
11	土	1	2	1	1	1	2	7	5	0	1	3	3	27	31	0	13	14	24	0.00	0.00	0.00	0.00	0.00	0.00	35	33	9	7	19	18
12	日	1	2	1	2	1	2	7	7	2	3	5	5	30	30	7	17	22	25	0.00	0.00	0.00	0.00	0.00	0.00	30	30	14	7	20	18
13	月	1	3	1	2	1	2	7	6	2	2	4	4	29	31	5	15	19	24	0.00	0.00	0.00	0.00	0.00	0.00	30	31	7	6	18	17
14	火	1	2	0	2	1	2	6	6	0	1	3	4	24	28	0	7	13	21	0.00	0.00	0.00	0.00	0.00	0.00	29	37	9	6	19	16
15	水		2		1		2		7		3		5		32		18		26		0.00		0.00		0.00		30		8		19
16	木		2		2		2		6		2		4		29		14		23		0.00		0.00		0.00		34		7		19
17	金		2		2		2		8		2		4		30		8		25		0.00		0.00		0.00		36		8		21
18	土		2		1		2		7		4		5		35		16		25		0.00		0.00		0.00		33		5		18
19	日		2		2		2		6		1		4		34		10		25		0.00		0.00		0.00		31		6		18
20	月		2		1		2		7		1		4		32		4		26		0.00		0.00		0.00		32		9		19
21	火		6		1		2		7		2		5		31		7		24		0.00		0.00		0.00		29		6		16
22	水		2		1		2		7		2		4		30		12		24		0.00		0.00		0.00		30		12		20
23	木		2		1		2		7		1		5		30		3		24		0.00		0.00		0.00		30		8		18
24	金		2		2		2		7		2		5		29		12		21		0.00		0.00		0.00		30		8		19
25	土		2		2		2		8		4		6		29		15		23		0.00		0.00		0.00		31		8		17
26	日		2		1		2		7		4		5		30		15		25		0.00		0.00		0.00		31		8		19
27	月		5		2		2		7		4		7		28		17		24		0.00		0.00		0.00		32		9		20
28	火		2		2		2		7		2		5		33		21		28		0.00		0.00		0.00		35		13		21
29	水		2		2		2		8		2		4		32		20		28		0.00		0.00		0.00		34		10		21
30	木		2		2		2		7		4		6		34		21		27		0.00		0.00		0.00		31		10		20
最大		1	6	1	2	1	2	7	8	2	4	5	7	31	35	11	21	22	28	0.00	0.00	0.00	0.00	0.00	0.00	40	37	14	13	21	21
最小		1	2	0	1	1	1	5	4	0	1	2	3	20	28	0	3	13	19	0.00	0.00	0.00	0.00	0.00	0.00	29	27	6	5	18	16
平均		1	2	0	1	1	2	6	6	1	2	3	4	28	31	5	13	17	24	0.00	0.00	0.00	0.00	0.00	0.00	32	31	10	8	19	18
自主規制値		30				ppm		20				ppm		50				ppm		0.01				g/m <sup>3</sup> N		50				ppm	
法規制値		30				ppm		3,500				ppm 相当		430				ppm		0.04				g/m <sup>3</sup> N		250				ppm	
※ 備考	運転管理に基づき 1号炉 9月14日立下げ <span style="background-color: #cccccc; display: inline-block; width: 1em; height: 1em; vertical-align: middle;"></span> 休炉																														